


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

| | | | | | | |
|---|-------------------------|-----------------------------------|--|--|------------------------------|-------------------------------|
| 1 Location of well: | County Kearny | Township name Southside | Fraction Pivot NW¹/₄ | Section number 23 | Town number T 25 S | Range number R 35 W |
| Distance and direction from nearest town or city: 7 south, 1 west of Deerfield, Ks. | | | | 3 Owner of well: Jack Campbell Address: Lakin, Ks. 67860 | | |
| Locate with "X" in section below: N  W E S 1 Mile | | Sketch map: | | 4 Well depth: 357 ft. Date of completion 4-15-75 Well diameter 26 in. | | |
| 2 Type and color of material | | | | 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | |
| | | | | 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well | | |
| | | | | 7 Casing: Material Steel Weight: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 36.87 lbs./ft. 1 16 in. to 358 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth | | |
| | | | | 8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot/gauge _____ Length 20' Set between 250 ft. and 270 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2" down | | |
| | | | | 9 Static water level: 65 ft. below land surface Date 2-19-75 | | |
| | | | | 10 Pumping level below land surfaces: 77 ft. after 2 hrs. pumping 818 g.p.m. 83 ft. after 4 hrs. pumping 1236 g.p.m. Estimated maximum yield 1200 g.p.m. | | |
| | | | | 11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ | | |
| | | | | 12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade | | |
| | | | | 13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft. | | |
| | | | | 14 Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| (use a second sheet if needed) | | | | 15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless-FMC Model number 03879 HP 100 Volts _____ Length of drop pipe 160 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| 16 Remarks: elevation Located in the sand hills. Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | 17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name _____ License No. _____ Address Box 493 Garden City, Ks. Signed [Signature] Date 6-10-75 Authorized representative | | |

The Professionals

MINNER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JACK CAMPBELL
Kearny ~~Finney~~ County
2-19-75

Location: Nw⁴ 23-25-35 Pivot

Static Water Level - 65'

Test # 2

| | | |
|-----|-----|--|
| 0 | 26 | Fine to med. sand |
| 26 | 67 | Med. to coarse gravel (Loose) |
| 67 | 80 | Brown clay |
| 80 | 129 | Fine to med. sand & gravel (Loose) |
| 129 | 155 | Brown & blue clay |
| 155 | 170 | Blue clay |
| 170 | 234 | Fine to med. sand & gravel (Loose) |
| 234 | 245 | Fine to med. sand & gravel 30% clay |
| 245 | 269 | Fine to med. sand & gravel (Loose) |
| 269 | 290 | Brown sandy clay & white rock |
| 290 | 302 | Brown sandy clay streaks of gravel 35% (Loose) |
| 302 | 357 | Fine to med. sand & gravel 10% clay (Loose) |
| 357 | 386 | Brown sandy clay & gray clay |
| 386 | 395 | Brown gray & yellow clay (Hard) |

TD - 357'