


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Kearny	Township name Southside	Fraction Pivot NE 1/4	Section number 23	Town number T 25 S	Range number R 35 W
Distance and direction from nearest town or city: 7 south, 1/2 west				3 Owner of well: Jack Campbell		
Street address of well location if in city: of Deerfield, Ks.				Address: Lakin, Ks. 67860		
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			
2 Type and color of material			From To		4 Well depth: <u>350</u> ft. Date of completion <u>4-9-75</u> Well diameter <u>26</u> in.	
					5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
					7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>351</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>16</u> in. to <u> </u> ft. depth	
					8 Screen: Manufacturer <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/groove <u>100</u> Length <u>20'</u> Set between <u>320</u> ft. and <u>340</u> ft. Perforations: <u>100-320, 340-350</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/2" down</u>	
					9 Static water level: <u>65</u> ft. below land surface Date <u>2-18-75</u>	
					10 Pumping level below land surfaces: <u>80</u> ft. after <u>2</u> hrs. pumping <u>907</u> g.p.m. <u>89</u> ft. after <u>4</u> hrs. pumping <u>1227</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <u> </u> Depth: From <u>0</u> ft. to <u>10</u> ft.	
14 Nearest source of possible contamination <u>N</u> <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-FMC</u> Model number <u>3877</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
16 Remarks: elevation Located in sand hills. Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Address <u>Box 493 Garden City, Ks.</u> Signed <u>Minter Wilson</u> Date <u>6-20-75</u> Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

~~Finney~~ Kearny County

Jack Campbell

February 18, 1975

NE $\frac{1}{4}$ sec. 23 T. 25 R. 35 Static Water Level 65 Test # 1

Location: Pivot

0	8	Sand & Clay (mixed)
8	53	Medium to Coarse Gravel (Loose)
53	65	Brown Clay
65	113	Fine to Medium Sand & Gravel (Loose)
113	133	Blue Clay
133	141	Fine to Medium Sand & Gravel (Loose)
141	155	Brown Sandy Clay, small streak of Gravel 30%
155	170	Fine to Medium Sand & Gravel 30% Clay
170	183	Brown Sandy Clay
183	206	Fine to Medium Sand & Gravel (Loose)
206	215	Brown Clay
215	248	Fine to Medium Sand & Gravel (Loose)
248	264	Fine to Medium Sand & Gravel 10% Clay (Loose)
264	288	Brown Sandy Clay
288	295	Fine to Medium Sand & Gravel 15% Clay (Loose)
295	303	Brown Sandy Clay
303	320	Fine to Medium Sand & Fine Gravel 10% Clay (Loose)
320	350	Fine to Medium Sand & Gravel (Loose)
350	378	Fine to Medium Sand & Gravel 15% Clay (Loose)
378	402	Fine to Medium Sand & Gravel 20% Clay (Loose)
402	417	Brown Sandy Clay
417	425	Brown, Gray & Yellow Clay (Hard)