

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Kearny</b>	Fraction <b>SW 1/4 NW 1/4 SW 1/4</b>	Section number <b>25</b>	Township number <b>T 25 S R 35</b>	Range number <b>35</b>
2. Distance and direction from nearest town or city: <b>3 1/2 south, 1/4 east of Deerfield</b> Street address of well location if in city:			3. Owner of well: <b>Brad Tate</b> R.R. or street: <b>Lakin, KS 67860</b> City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>12-8-76</b> Well depth <b>320</b> ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From		9. Casing: Material <b>steel</b> Height: Above or below	
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>321</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No.	
				10. Screen: Manufacturer's name <b>J Inson</b>	
				Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <input type="checkbox"/> Length <b>20</b> Set between <b>290</b> ft. and <b>310</b> ft. <b>Perfl 120-290</b> ft. and <b>310-320</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/2" Down</b>	
				11. Static water level: <b>86</b> ft. below land surface Date <b>11-20-76</b>	
				12. Pumping level below land surfaces: <b>95</b> ft. after <b>2</b> hrs. pumping <b>800</b> g.p.m. <b>101</b> ft. after <b>4</b> hrs. pumping <b>1400</b> g.p.m. Estimated maximum yield <b>1400</b> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade	
				15. Well grouted? <b>yes</b>	
				With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
				16. Nearest source of possible contamination: <b>N/A</b>	
				ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <b>Field MW</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed	
				Manufacturer's name <b>Goulds US Pumps</b> Model number <b>76552</b> HP <b>125</b> Volts Length of drop pipe <b>160</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling 208</b> Business name License No. <b>24-7</b> Address <b>Box A Garden City, KS 67864</b> Signed <b>[Signature]</b> Date <b>2-24-77</b> Authorized representative		

25  
 35  
 25  
 25  
 Sec  
 1/4  
 NW  
 SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TATE  
KEARNY COUNTY  
11-3-76

Location: SW 25-25-35 8 $\frac{1}{2}$  mile south of river road on Deer-  
field Land  $\frac{1}{2}$  east  $\frac{1}{2}$  south  
Static Water Level- 80'

Test #2

0	22	Fine sand
22	34	Brown clay
34	97	Fine to med. sand and gravel
97	108	Brown clay
108	123	Fine to med. sand and gravel 15% clay
123	181	Fine to med. sand and gravel Loose
181	187	Brown sandy clay
187	239	Fine to med. sand and gravel Loose
239	277	Brown sandy clay
277	320	Fine to med. sand and gravel Loose
320	427	Brown sandy clay
427	436	Brown and yellow clay and brown rock
436	440	Shale

T.D. 320'