

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County <b>Kearny</b>	Fraction <b>NW 1/4 SE 1/4 NW 1/4</b>	Section number <b>25</b>	Township number <b>T 25 S R 35</b>	Range number <b>35</b>
2. Distance and direction from nearest town or city: <b>1 south, 1/2 east</b> <b>8 south, 1/4 east of Deerfield</b>			3. Owner of well: <b>Brad Tate</b> R.R. or street: <b>Lakin, KS 67860</b> City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>12-20-76</b> Well depth <b>382</b> ft.		
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
		9. Casing: Material <b>steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>388</b> depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <input type="checkbox"/> Length <b>20'</b> Set between <b>350</b> ft. and <b>370</b> ft. <b>Perf. 140-350</b> ft. and <b>370-382</b> ft. Gravel pack? <b>yes</b> Size range of material <b>2" DOWN</b>		
5. Type and color of material		From	To	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>81</b> ft. below land surface Date <b>11-20-76</b>		
				12. Pumping level below land surfaces: <b>106</b> ft. after <b>2</b> hrs. pumping <b>800</b> g.p.m. <b>122</b> ft. after <b>4</b> hrs. pumping <b>1350</b> g.p.m. Estimated maximum yield <b>1350</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <b>Field</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <b>Not installed</b> Manufacturer's name <b>Goulds U.S. Pumps</b> Model number <b>76556</b> HP <b>125</b> Volts <input type="checkbox"/> Length of drop pipe <b>160</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling</b> License No. <b>208</b> Address <b>Box A Garden City, KS 67846</b> Signed <b>[Signature]</b> Date <b>2-24-74</b> Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

25.35 @ 25 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

KEARNY COUNTY  
11-1-66

**Loc**

Location: NW 25-25-35 8 $\frac{1}{2}$  mile south of river road on  
Deerfield lane  $\frac{1}{2}$  east

Static Water Level- 80'

**Test #5**

0	12	Fine sand
12	23	Brown clay
23	97	Fine to med. sand and gravel with some coarse gravel
97	123	Brown clay
123	141	Fine to med. sand and gravel
141	168	Brown sandy clay
168	183	Blue clay
183	216	Fine to med. sand and gravel 10% clay
216	263	Fine to med. sand and gravel Loose
263	277	Fine to med. sand and gravel 10% clay
277	303	Fine to med. sand and gravel Loose
303	337	Brown sandy clay
337	382	Fine to med. sand and gravel 10% clay
382	456	Brown clay
456	467	Brown and yellow clay and brown rock
467	470	Shale

T.D. 382'

140' Plain  
210' Perf  
20' Screen  
12' Perf