


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

C-3A

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County <u>Kearny</u>	Fraction <u>1/4 1/4 1/4</u>	Section number <u>31</u>	Township number <u>T 25 S R 35 E/W</u>	Range number
2. Distance and direction from nearest town or city: <u>from Leikin 1 south 2 1/4 east 6 south 3/4 east 1/4 north</u> Street address of well location if in city:			3. Owner of well: <u>Wayne Thornbrough</u> R.R. or street: <u>45 Laurle St.</u> City, state, zip code: <u>Concord, Mass. 91742</u>		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>26</u> in. Completion date <u>4-30-76</u> Well depth <u>383</u> ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: <u>above</u> or <u>below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>381</u> ft. depth Wall thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219 MMS</u>		
			10. Screen: Manufacturer's name <u>Galv.</u> Type <u> </u> Dia. <u>16</u> Slot/gauze <u>100</u> Length <u>20</u> Set between <u>200-210</u> ft. and <u>360-370</u> ft. <u>120-200</u> ft. and <u>210-250, 370-383</u> ft. Gravel pack? <u>yes</u> Size range of material <u>3" Don</u>		
			11. Static water level: <u>72</u> ft. below land surface Date <u>4-20-76</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>91</u> ft. after <u> </u> hrs. pumping <u>1325</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1325</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
			14. Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <u> </u> inches above grade		
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u> </u> ft. to <u> </u> ft.		
			16. Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-MC</u> Model number <u>121B</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Monte Wilson Drilling 208</u> Business name Address <u>P.O. Box 4 Garden City, Mo.</u> Signed <u>Monte Wilson</u> Date <u>4-12-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

WORN BROUGH
(CARROLL-TELMANT)
NEARBY COUNTY
3-18-76

LOCATION: SE 31-25-35
600 Ft. North of Pivot

STATIC WATER LEVEL: 80'

TEST AC-3A

0	1	Top Soil
1	20	Fine Sand
20	110	Med. To Coarse Gravel
110	130	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
130	141	Blue Clay
141	150	Fine To Med. Sand, Streak Of Clay (10%)
150	155	Blue Clay
155	210	Fine To Med. Sand & Gravel (Loose)
210	220	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
220	245	Brown Sandy Clay, Streaks Of Fine To Med. Sand (30%)
245	251	Fine To Med. Sand (Loose)
251	260	Brown Sandy Clay
260	269	Fine To Med. Sand & Gravel (Loose)
269	299	Brown Sandy Clay
299	320	Fine To Med. Sand, Streak Of Clay (10%) (Loose)
320	340	Brown Sandy Clay, Streak Of Fine To Med. Sand (20%) (Tight)
340	360	Fine To Med. Sand & Fine Gravel, Streak Of Clay (10%)
360	383	Fine To Med. Sand & Fine Gravel (Loose)
383	390	Brown Clay & Yellow Clay (Hard)