


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>MOHAWK</u>	Fraction <u>SW 1/4 NE 1/4 SW 1/4</u>	Section number <u>32</u>	Township number <u>T 25 S R 35 E/W</u>	Range number
2. Distance and direction from nearest town or city: <u>From Lakin 1 south 2 1/2 east 6 south 1 1/2 east 1/4 north</u>			3. Owner of well: <u>Wayne Thornbrough</u> R.R. or street: <u>45 Laurel St.</u> City, state, zip code: <u>Concord, Mass. 01742</u>		
4. Locate with "X" in section below: 			6. Bore hole dia. <u>26</u> in. Completion date <u>1-30-76</u> Well depth <u>371</u> ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>26.87</u> lbs./ft. Dia. <u>1 1/2</u> in. to <u>270</u> ft. depth Wall thickness: inches or Dia. <u>1 1/2</u> in. to <u>371</u> ft. depth gage No. <u>2.1744</u>		
			10. Screens: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>270-280</u> ft. and <u>350-360</u> ft. <u>Part 110-270 ft. and 280-350-360 ft.</u> Gravel pack? <input type="checkbox"/> Size range of material <u>3/4" on</u>		
			11. Static water level: <u>60</u> mo./day/yr. <u>60</u> ft. below land surface Date <u>1-30-76</u>		
			12. Pumping level below land surface: <u>1300</u> <u>122'</u> ft. after <u>2</u> hrs. pumping <u>1300</u> g.p.m. <u>122'</u> ft. after <u>2</u> hrs. pumping <u>1300</u> g.p.m. Estimated maximum yield <u>1300</u> g.p.m.		
			13. Water sample submitted: <u>1300</u> mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date <u>1-30-76</u>		
			14. Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: <u>1/4</u> ft. <u>1/4</u> Direction <u>1/4</u> Type <u>1/4</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
17. Pump: <u>Not installed</u> Manufacturer's name <u>Peerless PD</u> Model number <u>12LB</u> HP <u>100</u> Volts <u>100</u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Walter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden City, Mo.</u> License No. <u>1/4 1/4 1/4</u> Address <u>1/4 1/4 1/4</u> Signed <u>Walter Wilson</u> Date <u>1-30-76</u> Authorized representative		

Sec
 T
 R
 S
 E
 W
 1/4
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

THOMSBROUGH
(FLETCHER-TENANT)

3-10-76

LOCATION: SW $\frac{1}{4}$ 32-25-35
600 Feet North of Pivot

STATIC WATER LEVEL

TEST #F-9A

0	1	Top Soil
1	12	Fine Sand
12	20	Brown Sandy Clay
20	77	Med. To Fine Gravel
77	125	Brown Sandy Clay
125	170	Brown Sandy Clay, Streaks Of Fine To Med. Sand & Gravel (30%)
170	208	Fine To Med. Sand & Gravel (Loose)
208	215	Brown Clay
215	231	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
231	263	Fine To Med. Sand & Gravel (Loose)
263	280	Fine To Med. Sand & Gravel, Streaks Of Clay (15%)
280	286	Brown Sandy Clay
286	291	Fine To Med. Sand & Gravel (Loose)
291	300	Fine To Med. Sand, Streak Of Clay (10%)
300	322	Fine To Med. Sand, Streak Of Clay (15%)
322	350	Brown Sticky Clay, Small Streaks Of Fine Sand (No Good)
350	360	Fine To Med. Sand (Loose)
360	371	Fine To Med. Sand & Fine Gravel (Loose)
371	377	Yellow Clay
377	380	Shale