

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

7-P

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Kearny</u>	Fraction <u>III 1/4 SE 1/4 III 1/4</u>	Section number <u>32</u>	Township number <u>T 25 S R 35</u>	Range number <u>EW</u>
2. Distance and direction from nearest town or city: <u>1/4 mile from Lakin 1 south 2 1/4 east 5 south 1 1/4 east 1/4 south</u>			3. Owner of well: <u>Wayne Thorbrough</u> R.R. or street: <u>45 Laurel St.</u> City, state, zip code: <u>Concord, Mass 97112</u>			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>4-10-76</u> Well depth <u>390</u> ft.	
					7. <input type="checkbox"/> Coble tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height: <u>Above or below</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>10</u> in. to <u>390</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219 MNC</u>		
				10. Screen: Manufacturer's name <u>JOHNSON DIVISION</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>260</u> ft. and <u>280</u> ft. Perf. <u>120-260</u> ft. and <u>280-390</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1" Norm</u>		
				11. Static water level: <u>76</u> ft. below land surface Date <u>4-7-76</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>20</u> ft. after <u> </u> hrs. pumping <u>1500</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.		
				13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date <u> </u>		
				14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter <u> </u> inches above grade		
				15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>WD- Peerless Pump</u> Model number <u>1215</u> HP <u>1000</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Hunter Wilson Drilling 208</u> Business name: <u>O. Box A Garden City, Mo.</u> Address <u> </u> Signed <u>Wayne Thorbrough</u> Date <u>8-12</u> Authorized representative
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

GRANT THORNBROUGH
(Fletcher Tenant)
KEARNEY COUNTY
2-25-76

LOCATION: NW 32-25-35
30 Feet West Of Pivot

STATIC WATER LEVEL: 80'

TEST # F-8

0	1	Top Soil
1	12	Fine Sand
12	22	Brown Clay
22	80	Med. To Coarse Gravel, Streaks Of Clay (10%)
80	97	Brown Sandy Clay
97	110	Fine To Med. Sand & Gravel, Streaks Of Clay (30%)
110	140	Fine To Med. Sand & Gravel (Loose)
140	153	Blue & Gray Clay, Streaks Of Fine To Med. Sand & Gravel (10%)
153	178	Blue Clay
178	185	Fine To Med. Sand & Gravel (Loose)
185	230	Fine To Med. Sand & Gravel, Streaks Of Clay (20%) Tight
230	241	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
241	280	Fine To Med. Sand & Gravel (Loose (Took Water))
280	290	Fine To Med. Sand & Gravel, Streaks Of Clay (20%)
290	306	Brown Sandy Clay Small Streaks Of Gray Clay
306	335	Fine Sand & Clay Mixture (50%) No Good
335	354	Brown Sandy Clay, Small Streaks Of Fine Sand (Tight) No Good

-Cont-

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

GRANT THORNBROUGH
(Fletcher-Tenant)
KEARNEY COUNTY
2-25-76
-Cont-

354	366	Brown Sandy Clay & Fine To Med. Sand (50% Tight No Good
366	390	Fine To Med. Sand & Gravel, Streaks Of Clay (15%) Loose
390	395	Yellow Clay
395	400	Shale