


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 36	Township number T 25 S R 35 10	Range number 35 10
2. Distance and direction from nearest town or city: 1 south, 1/2 east 9 1/2 south, 1/2 east of Deerfield			3. Owner of well: Brad Tate R.R. or street: Lakin, KS 67860 City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 26 in. Completion date 12-13-76 Well depth 332 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 333 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20' Set between 260 ft. and 280 ft. Perf: 140-260 and 280-332 ft. Gravel pack? yes Size range of material 1/2" Down		
			11. Static water level: 66 ft. below land surface Date 12-2-76 mo./day/yr.		
			12. Pumping level below land surfaces: 132 ft. after 3 hrs. pumping 900 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 900 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds U.S. Pumps Model number 76561 HP 125 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. 46 Address Box A Garden City, KS 67846 Signed [Signature] Date 2-24-77 Authorized representative		

25 35 36 NW SE NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TATE
KEARNY COUNTY
11-5-76

Location: NW 36-25-35 9½ mile south of river road on
Deerfield lane ¼ east
Static Water Level- 80'

Test #4

0	6	Fine sand
6	13	Brown clay
13	21	Fine sand
21	63	Fine to med. sand and grav31
63	96	Brown clay
96	113	Brown blue clay
113	181	Fine to med. sand 15% clay
181	216	Fine to med. sand and gravel
216	229	Fine to med. sand and gravel tight stks. Pull down
229	292	Fine to med. sand and gravel
292	332	Fine to med. sand and gravel 10% clay
332	418	Brown sandy clay
418	425	Brown and yellow clay and brown rock

T.D.332'