

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction SW 1/4 SE 1/4	Section number 36	Township number T 25 S R 35	Range number 35																				
2. Distance and direction from nearest town or city: 1 south, 1/2 east Street address of well location if in city: 9 3/4 south 3/4 east of deerfield		3. Owner of well: Brad Tate R.R. or street: Lakin, KS 67860 City, state, zip code: 1																							
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile 1 Mile			6. Bore hole dia. steel in. Completion date 12-11-76 Well depth 365 ft.																						
5. Type and color of material <table border="1" style="width:100%;"><thead><tr><th>From</th><th>To</th></tr></thead><tbody><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr><tr><td> </td><td> </td></tr></tbody></table>			From	To																			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			From	To																					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																									
9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 1.6 in. to 366 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <input type="checkbox"/>																									
10. Screen: Manufacturer's name Johnson Type Galv Dia. 16" Slot/gauze <input type="checkbox"/> Length 201 Set between 270 ft. and 290 ft. Perf: 140-270 and 290-365 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 2" DOWN																									
11. Static water level: 97 ft. below land surface Date 12-1-76 mo./day/yr.																									
12. Pumping level below land surfaces: 124 ft. after 2 hrs. pumping 1025 g.p.m. 149 ft. after 4 hrs. pumping 2025 g.p.m. Estimated maximum yield 2000 g.p.m.																									
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>																									
14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 12 inches above grade																									
15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																									
16. Nearest source of possible contamination: Field ft. Direction N/A Type Field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																									
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds U.S. Pumps Model number 76752 HP 125 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																									
(Use a second sheet if needed)																									
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Business name License No. <input type="checkbox"/> Address Box A Garden City, KS Signed: [Signature] Date 3-24-74 Authorized representative																							

76
25
35
36
108
109
110
111
112
113
114
115

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TATE
KEARNY COUNTY
11-9-76

Location: SE 36-25-35 9 3/4 south of river road on Deerfield
Lane 3/4 east
Static Water Level- 80'

Test #2

0	34	Fine sand
34	127	Fine to med. sand and gravel
127	133	Fine to med. sand and gravel 20% clay
133	171	Fine to med. sand and gravel
171	184	brown sandy clay
184	216	Fine to med. sand and gravel
216	243	Brown sandy clay
243	292	Fine to med. sand and gravel
292	354	Brown sandy clay
354	365	Fine to med. sand and gravel
365	414	Brown sandy clay
414	425	Brown and yellow clay

T.D. 365