

## 21389

KSA 82a-1212

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269

• P.O. Box A

• GARDEN CITY, KANSAS 67846

Dale Yost  
Kearny County  
6-17-06

Location: SE $\frac{1}{4}$  12-25-35 - Deerfield Lane - 5 miles south,  $\frac{1}{2}$  mile east,  
 $\frac{1}{4}$  mile south &  $\frac{1}{4}$  mile east to well  
-  $\frac{1}{4}$  mile northeast

Static Water Level - 210 ft.

## Test #3

0' to 1' - Top soil  
1' to 31' - Fine sand - loose  
31' to 50' - Fine to medium sand & gravel  
50' to 95' - Medium coarse gravel  
95' to 103' - Brown clay  
103' to 117' - Fine to medium sand & gravel  
117' to 136' - Brown clay  
136' to 147' - Fine to medium sand & gravel  
147' to 155' - Brown clay  
155' to 168' - Fine to medium sand & gravel  
168' to 193' - Brown gray clay  
193' to 196' - Fine to medium sand & gravel  
196' to 209' - Brown clay  
209' to 213' - Fine to medium sand & gravel  
213' to 232' - Brown clay  
232' to 237' - Fine to medium sand  
237' to 246' - Brown clay  
246' to 260' - Fine to medium sand & gravel - 10% clay  
260' to 282' - Fine to medium sand & gravel  
282' to 303' - Brown clay  
303' to 308' - Fine sand  
308' to 322' - Fine to medium sand & gravel  
322' to 359' - Brown clay  
359' to 365' - Fine to medium sand & gravel  
365' to 376' - Brown clay - tight  
376' to 390' - Brown yellow red clay - hard  
390' to 410' - Shale