


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 25	Township number T 25 S R	Range number 35 (KW)
2. Distance and direction from nearest town or city: 1 south, 1/2 east 8 1/2 south, 3/4 east of Deerfield Street address of well location if in city:			3. Owner of well: Brad Tate R.R. or street: Lakin, Ks 67860 City, state, zip code:		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 12-9-76 Well depth 381 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>382</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>		
			10. Screen: Manufacturer's name <u>J Inson</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>20'</u> Set between <u>350</u> ft. and <u>370</u> ft. Perf: <u>140-350</u> ft. and <u>370-381</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/2" Down</u>		
			11. Static water level: <u>82</u> ft. below land surface Date <u>11-8-76</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>147</u> ft. after <u>3</u> hrs. pumping <u>2050</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>2080</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u>Field muc</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goolds U.S. Pumps</u> Model number <u>76549</u> HP <u>125</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling</u> <u>208</u> Business name Address <u>Box A Garden City, KS 67841</u> License No. <u>84</u> Signed <u>[Signature]</u> Date <u>1-24-77</u> Authorized representative		

T 25 S R 35 E Sec 25 NE NE NE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TATE
KEARNY COUNTY
11-2-76

Location NE 25-25-35 8 $\frac{1}{4}$ mile south of River road on
Deerfield Lane 3/4 east
Static Water Level- 80'

Test #1		
0	33	Fine sand
33	111	Fine to med. sand and gravel with some coarse gravel
111	127	Brown clay
127	142	Fine to med. sand and gravel 15% clay
142	157	Blue clay
157	169	Fine to med. sand and gravel 15%
169	202	Fine to med. sand and gravel 10%
202	214	Brown sandy clay
214	231	Fine to med. sand and gravel 10% clay
213	264	Brown sandy clay
264	304	Fine to med. sand and gravel Loose
304	337	Brown sandy clay
337	381	Fine to med. sand and gravel
381	442	Brown sandy clay
442	451	Brown and yellow clay
451	455	Shale

T.D. 381