

**WATER WELL RECORD**

**Form WWC-5**

Division of Water Resources App. No.

24,380

<b>1 LOCATION OF WATER WELL:</b> County: <b>KEARNY</b>	Fraction $\frac{1}{4}$ NE $\frac{1}{4}$ SE $\frac{1}{4}$ SW $\frac{1}{4}$	Section Number <b>32</b>	Township No. T <b>25</b> S	Range Number R <b>35</b> <input type="checkbox"/> E <input checked="" type="checkbox"/> W
-----------------------------------------------------------	------------------------------------------------------------------------------	-----------------------------	-------------------------------	----------------------------------------------------------------------------------------------

Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here .  
**LAKIN-S SIDE - 1 M S, 1/4 M E TO LAKIN LANE, 6 M S, 4 M E, 900 FT. NORTH & 3,125 FT. WEST**

**Global Positioning System (GPS) information:**  
 Latitude: **37.83113** (in decimal degrees)  
 Longitude: **-101.18722** (in decimal degrees)  
 Elevation: .....  
 Datum:  WGS 84,  NAD 83,  NAD 27  
 Collection Method:  
 GPS unit (Make/Model: **GARMIN 62ST**)  
 Digital Map/Photo,  Topographic Map,  Land Survey  
 Est. Accuracy:  <3 m,  3-5 m,  5-15 m,  >15 m

**2 WATER WELL OWNER:** **BLUE HOUSE FAMILY TRUST**  
 RR#, Street Address, Box #: **455 NE 5TH AVE.-SUITE D. #312**  
 City, State, ZIP Code : **DELRAY BEACH, FL 33483**

**3 LOCATE WELL WITH AN "X" IN SECTION BOX:**  
 N  

W	-- NW --	-- NE --	E
	-- SW --	<b>X</b> -- SE --	
	S		

 -----1 mile-----

**4 DEPTH OF COMPLETED WELL** **500** ft.  
 Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft.  
 WELL'S STATIC WATER LEVEL **253** ft. below land surface measured on mo/day/yr. **6-5-12**  
 Pump test data: Well water was..... ft. after..... hours pumping..... gpm  
 EST. YIELD..... gpm. Well water was..... ft. after..... hours pumping..... gpm  
 Bore Hole Diameter **30** in. to **500** ft., and ..... in. to ..... ft.  
 WELL WATER TO BE USED AS:  Public water supply  Geothermal  Injection well  
 Domestic  Feedlot  Oil field water supply  Dewatering  Other (Specify below)  
 Irrigation  Industrial  Domestic-lawn & garden  Monitoring well .....  
 Was a chemical/bacteriological sample submitted to Department?  Yes  No  
 If yes, mo/day/yr sample was submitted.....  
 Water well disinfected?  Yes  No

**5 TYPE OF CASING USED:**  Steel  PVC  Other .....  
 CASING JOINTS:  Glued  Clamped  Welded  Threaded  
 Casing diameter **16** in. to **275** ft., Diameter ..... in. to ..... ft., Diameter ..... in. to ..... ft.  
 Casing height above land surface **12** in., Weight **42.05** lbs./ft., Wall thickness or gauge No. **250**  
 TYPE OF SCREEN OR PERFORATION MATERIAL:  
 Steel  Stainless Steel  PVC  Other (Specify) .....  
 Brass  Galvanized Steel  None used (open hole)  
 SCREEN OR PERFORATION OPENINGS ARE:  
 Continuous slot  Mill slot  Gauze wrapped  Torch cut  Drilled holes  None (open hole)  
 Louvered shutter  Key punched  Wire wrapped  Saw cut  Other (specify) .....  
 SCREEN-PERFORATED INTERVALS: From **275** ft. to **415** ft., From **435** ft. to **500** ft.  
 From ..... ft. to ..... ft., From ..... ft. to ..... ft.  
 GRAVEL PACK INTERVALS: From **20** ft. to **200** ft., From **260** ft. to **500** ft.  
 From ..... ft. to ..... ft., From ..... ft. to ..... ft.

**6 GROUT MATERIAL:**  Neat cement  Cement grout  Bentonite  Other .....  
 Grout Intervals: From **0** ft. to **20** ft., From **200** ft. to **260** ft., From ..... ft. to ..... ft.  
 What is the nearest source of possible contamination:  
 Septic tank  Lateral lines  Pit privy  Livestock pens  Insecticide storage  Other (specify below)  
 Sewer lines  Cesspool  Sewage lagoon  Fuel storage  Abandoned water well  
 Watertight sewer lines  Seepage pit  Feedyard  Fertilizer storage  Oil well/gas well **N/A**  
 Direction from well ..... Distance from well .....

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHO. LOG (cont.) or PLUGGING INTERVALS
0	275	16" PLAIN CASING			
275	335	16" JOHNSON AGRI SCREEN			
335	355	16" MILL SLOT PERF.			
355	415	16" JOHNSON AGRI SCREEN			SEE ATTACHED LOG
415	435	16" PLAIN CASING			
435	495	16" JOHNSON AGRI SCREEN			
495	500	16" MILL SLOT PERF.			

**7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION:** This water well was  constructed,  reconstructed, or  plugged under my jurisdiction and was completed on (mo/day/year) **6-5-12** and this record is true to the best of my knowledge and belief.  
 Kansas Water Well Contractor's License No. **208** This Water Well Record was completed on (mo/day/year) .....  
 under the business name of **MINTER-WILSON DRILLING CO., INC.** by (signature) *Nora Keller*

**INSTRUCTIONS:** Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks and check the correct answers. Send three copies (white, blue, pink) to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5524. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at <http://www.kdheks.gov/waterwell/index.html>.

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME FLETCHER RANCH - CIRCLE # 42  
COUNTY KEARNY  
DATE 3-5-12

LOCATION: SW 1/4 32-25-35 - SOUTHEAST PART OF CIRCLE

STATIC WATER LEVEL -

### TEST # 3

0' TO 9' - FINE SAND  
9' TO 14' - BROWN CLAY  
14' TO 100' - FINE TO MEDIUM SAND & GRAVEL - SOME COARSE  
WITH LAYERS OF BROWN SANDY CLAY  
100' TO 160' - FINE TO MEDIUM SAND & GRAVEL  
WITH LAYERS OF BROWN SANDY CLAY  
160' TO 175' - BROWN SANDY CLAY  
WITH STRIPS OF SAND & GRAVEL  
175' TO 195' - BLUE CLAY  
195' TO 203' - BROWN SANDY CLAY  
203' TO 212' - FINE TO MEDIUM SAND & GRAVEL  
WITH LAYERS OF BROWN SANDY CLAY  
212' TO 240' - BROWN SANDY CLAY  
240' TO 254' - FINE TO MEDIUM SAND & GRAVEL  
254' TO 262' - BROWN SANDY CLAY  
262' TO 280' - FINE TO MEDIUM SAND & GRAVEL  
WITH STRIPS OF BROWN SANDY CLAY - 20%  
280' TO 287' - BROWN SANDY CLAY  
287' TO 289' - FINE TO MEDIUM SAND & GRAVEL  
289' TO 301' - BROWN SANDY CLAY  
301' TO 318' - FINE TO MEDIUM SAND  
WITH LAYERS OF BROWN SANDY CLAY - 30%  
318' TO 373' - BROWN SANDY CLAY  
WITH STRIPS OF WHITE ROCK  
373' TO 387' - FINE TO MEDIUM SAND  
WITH LAYERS OF BROWN SANDY CLAY - 15%  
387' TO 400' - BROWN, YELLOW & WHITE CLAY  
WITH 20% BROWN ROCK  
400' TO 403' - LOOSE BROWN ROCK  
403' TO 415' - BROWN, YELLOW & WHITE CLAY  
WITH 20% BROWN ROCK  
415' TO 446' - SHALE & WHITE SANDY CLAY MIXED  
446' TO 453' - SHALE WITH STRIPS OF FINE SAND - 30%  
453' TO 460' - SHALE  
460' TO 465' - SHALE WITH STRIPS OF FINE SAND  
465' TO 473' - FINE SAND & BROWN ROCK  
473' TO 481' - SHALE  
481' TO 485' - ? SAND STONE - LOST CIRCULATION