


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 1	Township number T 25 S R 36	Range number 1/W
2. Distance and direction from nearest town or city: 1/2 south of the river bridge at Lakin, 1 3/4 east, Street address of well location if in city: 3/4 south			3. Owner of well: Martin Vann R.R. or street: Lakin, Ks. 67860 City, state, zip code:		
4. Locate with "X" in section below: N  W E S 1 Mile			6. Bore hole dia. 26 in. Completion date 10-28-76 Well depth 276 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above <input type="checkbox"/> Below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 277 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .250		
			10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 3/32" Length 20 ft. Set between 250 ft. and 270 ft. Perf: 70-90 ft. and 170-250, 270-276 ft. Gravel pack? yes Size range of material 2" down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 22 ft. below land surface Date 8-27-76		
			12. Pumping level below land surfaces: 115 ft. after 3 hrs. pumping 1600 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1600 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Byron-Jackson Model number <input type="checkbox"/> HP 100 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A Garden City, Ks. Signed <i>[Signature]</i> Date 5-13-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

25-360
1-1/4 SE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Martin Vann
Kearny County
6-4-76

Location: From house $\frac{1}{2}$ mile East, $\frac{1}{2}$ mile South, $\frac{1}{2}$ mile West,
500' South SE $\frac{1}{4}$ 1-25-36

0	3	Top soil
3	57	Med. to coarse sand & gravel (loose)
57	88	Med. to coarse sand & gravel with tan clay
88	107	Tan clay
107	167	Blue clay
167	191	Fine to med. sand & gravel, tan clay streaks 20%
191	202	Fine to med. sand & gravel
202	223	Sandy tan clay
223	276	Fine to med. sand & gravel
276	298	Sandy tan clay
298	305	Shale

Static Water Level: 20

T.S. 276'