

USE TYPEWRITER OR BALL POINT PEN. PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Kearny	Fraction SE 1/4 NE 1/4 NW 1/4	Section number 3	Township number T 25 S R 36	Range number 36
2. Distance and direction from nearest town or city: 1 S. and 3/4 W. of Lakin Street address of well location if in city:				3. Owner of well: Ed Davis R.R. or street: City, state, zip code: Holcomb, KS 67851		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>4-15-76</u> Well depth <u>253</u> ft.		
		<p style="text-align: center;">Well drilled 4/12/76</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height: <u>(Above)</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>32</u> lbs./ft. Dia. <u>16</u> in. to <u>253</u> ft. depth Wall Thickness: inches or Dial <u>16</u> in. to <u>253</u> ft. depth gage No. <u>188</u>		
See attachment				10. Screen: Manufacturer's name <u>Brown</u> Type <u>Louvered</u> Dia. <u>16"</u> Slot/gauze <u>1/8"</u> Length <u>70'</u> Set between <u>180</u> ft. and <u>250</u> ft. ft. and <u> </u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/4 x 1/8</u>		
				11. Static water level: <u> </u> mo./day/yr. <u>18</u> ft. below land surface Date <u>4-15-76</u>		
				12. Pumping level below land surfaces: <u>103</u> ft. after <u> </u> hrs. pumping <u>1435</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.		
				13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>None observed</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. <u> </u> Address <u>Box 639, Garden City, KS</u> Signed <u>J. Henkle</u> Date <u>5-5-76</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

T 25 S
 R 36
 E
 Sec 03
 SE
 SE
 NW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME O. E. (Ed) Davis DATE 3-25-75
 STREET ADDRESS _____ TEST # 1 E. Log 280 Ft.
 CITY & STATE Holcomb, Kansas DRILLER Rector
 COUNTY Kearny QUARTER _____ NWSECTION 3 TOWNSHIP 25 RANGE 36

LOCATION 1320 Ft. South of NE corner of 1/4 and 50 Ft. West of East Side

Samples brought in.

WELL LOCATION

No	DRILLED		FOOTAGE	Description of Strata	Static Water Level _____ Proposed Well Depth _____
	from	Pay to			
	0		3	Top soil	
	3		8	Sand fine med. coarse, med., small gravel.	
	8		46	Sand and gravel, med. coarse, small. Large gravel.	
	46		56	Brown sandy clay and sand, med. coarse.	
	56		60	Sand fine med. coarse, small gravel.	
55	60	40	100	Brown sandy clay, sand fine med. coarse and med., small. Used lots of water. Mud heavy.	
	100		110	Brown clay	
40	110	15	125	Brown sandy clay and sand fine to med.	
65	125	20	145	Sand fine med. coarse, small coarse, small gravel. Few, small clay st. Used lots of water. Mud heavy.	
	145		160	Brown sandy clay	
60	160	22	182	Sand and gravel, fine med. coarse, small gravel. Loose. Used lots of water. Mud heavy. Good	
	182		186	Brown sandy clay	
65	186	14	200	Sand and gravel, fine med. coarse, small gravel and few, small white and tan rock. Loose. Used lots of water. Mud heavy. Good.	
	200		207	Brown sandy clay, sand and limrock	
65	207	33	240	Sand, fine med. coarse, small coarse and few, small clay st. Loose. Used water.	
70	240	11	251	Sand fine med. coarse, small gravel. Loose. Used water.	
	251		264	Brown clay, firm.	
	264		278	Brown sandy clay, sand	
	278		280	Brown clay, firm.	
	155			Used 12 Sacks Quick Gel 10# Lime Set up face south. Pit on West.	
				TOTAL DEPTH OF WELL POSSIBLY 253 Ft.	