


USE TYPEWRITER OR BALL POINT P I-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County KEARNY	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 7	Township number T 25 S R	Range number 36 EW
2. Distance and direction from nearest town or city: 1 south of Lakin 2 west 1 south 2 9/10 west north sdde of road Street address of well location if in city:			3. Owner of well: Clyde Beymer R.R. or street: Lakin, KS 67860 City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 5-30-76 Well depth 130 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 131 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MNC		
			10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 99 ft. and 109 ft. Perf. 30-99 ft. and 109-130 ft. Gravel pack? yes Size range of material 1/2" Down		
			11. Static water level: 24 ft. below land surface Date 6-17-76 mo./day/yr.		
			12. Pumping level below land surfaces: 30 ft. after 3 hrs. pumping 1390 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1390 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. N/A		
16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless Pump FMC Model number 121B HP 100 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name Address P.O. Box A, Garden City, KS License No. <input type="checkbox"/> Signed <i>[Signature]</i> Date 7-22-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

25
36
7
SW NE SW
1/4 1/4 1/4
Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professional
Engineers

WINTER WILSON DRILLING CO.
INCORPORATED

Installation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 777-6001 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

C. E. Beymer
Kearny County
5-20-75

Location: South of Lakin, 2 miles to west, 1 south,
2 9/10 west, north side of road, 80 ft. south of
old well house SW $\frac{1}{4}$ 7-25-36

Test # 1

0	1	Top Soil
12	109	Coarse gravel (loose)
109	125	Blue, gray clay
125	130	Med. sand, gravel
130	160	Brown sandy clay
160	170	Fine to med. sand (good, loose)

Static Water Level: 25'

T.D. 130' XXX

10' Screen