


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Kearney</u>	Fraction <u>1 1/4 SE 1/4 1 1/4</u>	Section number <u>13</u>	Township number <u>T 25 S R 36 NW</u>	Range number
2. Distance and direction from nearest town or city: <u>1 1/4 south, 1 3/4 east, 3/4 north of Latin, Ks.</u> Street address of well location if in city:				3. Owner of well: <u>Winter-Wilson Drilling Co.</u> R.R. or street: <u>Box 1</u> City, state, zip code: <u>Garden City, Ks. 67846</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>2-29-76</u> Well depth <u>360</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>steel</u> Height: <u>Above or below</u> m/c Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>361</u> ft. depth Wall Thickness: inches or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>219 m/c</u>		
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>220-230</u> ft. and <u>340-350</u> ft. Perf. <u>140-220</u> ft. and <u>230-340, 350-360</u> Gravel pack? <u>yes</u> Size range of material <u>3/4" down</u>		
				11. Static water level: <u>50</u> ft. below land surface Date <u>2-9-76</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>126</u> ft. after <u>2</u> hrs. pumping <u>600</u> g.p.m. <u>110</u> ft. after <u>4</u> hrs. pumping <u>1050</u> g.p.m. Estimated maximum yield <u>1050</u> g.p.m.		
				13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>2-9-76</u> mo./day/yr.		
				14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds US Pumps</u> Model number <u>12 JHC</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter-Wilson Drilling 208</u> Business name <u>Box 1 Garden City, Ks.</u> Address <u> </u> Signed <u>Ken Defenses</u> Date <u>2-3-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO. Complete Installation
INCORPORATED and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Minter-Wilson
Kearny County
12-20-75

Location: NW 13-25-36
200 yards East of Pivot 25
East of Pipe line

Static Water Level - 80'

Test # 6

0	1	Top Soil
1	16	Fine Sand (Loose)
16	38	Med. Coarse Gravel (Loose)
38	43	Clay Brown
43	65	Med. Coarse Sand
65	134	Brown Sandy Clay
134	144	Blue Clay
144	161	Fine to Med. Sand (Loose)
161	184	Blue Clay
184	208	Med. to Coarse Sand
208	236	Fine to Med. Sand
236	251	Sand Clay Brown
251	264	Fine Sand (Hard)
264	324	Sandy Clay
324	357	Sand Fine (Loose)
357	397	Sandy Clay
397	402	Brown Rock
402	430	Black Shale
		T.D. 360'