



USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>KEARNY</b>	Fraction <b>SW 1/4 NE 1/4 SW 1/4</b>	Section number <b>14</b>	Township number <b>T 25 S R 36 E/W</b>	Range number
2. Distance and direction from nearest town or city: <b>4 south, 1/2 east</b> <b>1/2 north to Lakin, Ks.</b> Street address of well location if in city:			3. Owner of well: <b>Hinter-Wilson Drilling Co.</b> R.R. or street: <b>Box A</b> City, state, zip code: <b>Garden City, Ks. 67846</b>			
4. Locate with "X" in section below: 			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. <b>26</b> in. Completion date <b>2-29-76</b> Well depth <b>313</b> ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <b>steel</b> Height: Above or below <b>MAC</b> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>314</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <b>219 MAC</b>	
					10. Screen: Manufacturer's name <b>Johnson Division</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <b>100</b> Length <b>20'</b> Set between <b>175-185</b> ft. and <b>295-305</b> ft. Perforations <b>120-175</b> ft. and <b>185-295, 305-313</b> ft. Gravel pack? <b>yes</b> Size range of material <b>3/4" Down</b>	
					11. Static water level: <input type="checkbox"/> mo./day/yr. <b>58</b> ft. below land surface Date <b>2-8-76</b>	
					12. Pumping level below land surfaces: <b>92</b> ft. after <b>3</b> hrs. pumping <b>1325</b> p.m. <b>1</b> ft. after <b>1 1/2</b> hrs. pumping <b>1325</b> g.p.m. Estimated maximum yield <b>1325</b> g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
					14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade	
					15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
					16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <b>Goulds 1500</b> <b>Not installed</b> Manufacturer's name <b>J.H.C.</b> Model number <b>100</b> HP <b>1000</b> Valts <b>1000</b> Length of drop pipe <b>160</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Hinter-Wilson Drilling 208</b> Business name <b>Box A Garden City, Ks.</b> Address <b>Box A Garden City, Ks.</b> Signature <b>[Signature]</b> Date <b>2-3-76</b> Authorized representative	
18. Elevation:		19. Remarks: <div style="text-align: center;"></div>				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

*Minter-Wilson*

Chuck Jaeger  
Kearny County  
11-22-75

Location: SW 14-25-36  
23'6" East of Pivot point  
Circle # 28

Static Water Level: 80

Test # 1

0	2	Top Soil
2	9	Fine Sand
9	23	Fine to Med. Sand
23	71	Fine to Med. Sand & Gravel (Loose)
71	82	Med. To Coarse Gravel
82	97	Med. to Coarse Gravel, Streaks of Clay (10%)
97	124	Med. to Coarse Gravel, Streaks of Clay (25%)
124	153	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
153	215	Fine to Med. Sand & Gravel (Loose)
215	300	Brown Sandy Clay
300	309	Fine to Med. Sand & Gravel (Loose)
309	330	Brown Clay (Tight)
330		Lost Circulation