


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

#24

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>ICARITY</u>	Fraction <u>NE 1/4 SW 1/4 NE 1/4</u>	Section number <u>14</u>	Township number <u>T 25</u>	Range number <u>S 36 E/W</u>
2. Distance and direction from nearest town or city: <u>3 1/4 north of Lakin, Ks.</u> Street address of well location if in city:				3. Owner of well: <u>Hinter-Wilson Drilling Co.</u> R.R. or street: <u>Box A</u> City, state, zip code: <u>Garden City, Ks. 67846</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>3-31-76</u> Well depth <u>363</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From		To		9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u> </u> in. to <u> </u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219 mks</u>
						10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>240</u> ft. and <u>260</u> ft. Perf. <u>110-240</u> ft. and <u>260-363</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4" down</u>
						11. Static water level: <u>64</u> ft. below land surface Date <u>3-13-76</u> 12. Pumping level below land surfaces: <u>103</u> ft. after <u>2</u> hrs. pumping <u>775</u> g.p.m. <u>265</u> ft. after <u>4</u> hrs. pumping <u>1275</u> g.p.m. Estimated maximum yield <u>1275</u> g.p.m.
						13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
						14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
						15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
						16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <u>Not installed</u> Manufacturer's name <u>Hinter</u> Goulds Pumps Model number <u>12 JMC</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>160</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						(Use a second sheet if needed)
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Hinter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden City, Ks.</u> Address <u> </u> Signed <u>Robert D. Seiler</u> Date <u>8-3-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

✓
CHUCK JAEGER
Kearny County
1-7-76

Location: NE 14-25-36
100 yards South of Pivot

Static Water Level - 80'

Circle 24

0	1	Top Soil
1	20	Fine Sand
20	63	Med. to Coarse Sand & Gravel (Loose)
63	79	Fine to Med. Sand & Gravel (Loose)
79	110	Brown Sandy Clay
110	123	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
123	127	Brown Clay
127	136	Fine to Med. Sand & Gravel, Streaks of Clay (15%)
136	140	Brown Sandy Clay
140	151	Fine to Med. Sand, Streaks of Clay (20%) (Tight)
151	170	Fine to Med. Sand, Streaks of Clay (10%) (Loose)
170	187	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
187	200	Fine to Med. Sand, Streaks of Clay (10%)
200	221	Fine to Med. Sand & Gravel (Loose)
221	243	Fine to Med. Sand & Fine Gravel (Loose)
243	260	Fine to Med. Sand & Gravel (Loose)
260	289	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
289	301	Fine Sand & Clay mixture (Tight)
301	305	Fine to Med. Sand, Streaks of Clay (10%)
305	331	Fine Sand, Streaks of Clay (15%) (Tight)
331	340	Fine to Med. Sand, Streaks of Clay (10%)
340	352	Fine to Med. Sand, Streaks of Clay (20%) (Tight)
352	363	Fine to Med. Sand & Fine Gravel, Streaks of Clay (10%)
363	370	Fine to Med. Sand & Clay mixture (Tight)
370	380	Fine to Med. Sand, Streaks of Clay (20%) (Tight)

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHUCK JAEGER

Circle 24 (Continued)

380	391	Fine Sand (Tight)
391	400	Shale

T.D. 363'