

[illegible]

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Kearny Co. Feeders

Kearny Co.

8-27-85

Location: 18-25-36

Offset 260' North 30' East of old well

Static water level 36'

Test # 5

0 2 Top soil
2 146' Fine to medium sand & gravel (Loose)
14 326' Medium coarse gravel (Loose)
32 56 Brown clay
56 75 Blue clay
75 80 Blue clay, small strip of gravel
80 94 Blue clay
94 100 Fine to medium sand & gravel (Loose)
100 119 Blue clay
119 124 Blue clay, small streak of medium sand
124 134' Blue clay
134 153 Fine to medium sand & gravel (Loose)
153 157 Medium coarse gravel (Loose)
157 161 Fine to medium sand & gravel (Loose)
161 176' Fine to medium sand & gravel, small streak of
clay (loose)
176 182 Brown blue clay mixed
182 199' Brown sandy clay
199 206 Fine sand (Loose)
206 215 Brown sandy clay, very small gravel streak
215 218' Fine to medium sand & gravel (Loose)
218 260 Brown sandy clay, White rock mixed
260 275 Brown sandy clay, Brown Yellow rock mixed
275 296 Brown sandy clay, Brock rock Hard pull down
296 304' Brown sandy clay, Yellow clay, Brown rock
Hard pull down
304 320 Shale