


USE TYPEWRITER OR BALL
POINT PEN-PRESS CAREFULLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KEARNY	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 24	Township number T 25 S R 36	Range number 36
2. Distance and direction from nearest town or city: 3/4 south of Lakin, Ks.			3. Owner of well: Minter - Wilson Drilling Co. R.R. or street: Box A City, state, zip code: Garden City, Ks. 67846			
4. Locate with "X" in section below: 			Sketch map:		6. Bore hole dia. 26 in. Completion date 1-26-76 Well depth 360 ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material steel Height: Above or Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 361 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MAC	
					10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 320 ft. and 340 ft. Perf. 120-240 ft. and 300-320, 340-360 Gravel pack? yes Size range of material 1/2" Down	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 73 ft. below land surface Date 2-8-76	
					12. Pumping level below land surfaces: 96 ft. after 3 hrs. pumping 1400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1400 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 12 inches above grade	
					15. Well grouted: yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: Goulds - US Pumps Manufacturer's name 12JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					18. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name Box A Garden City, Ks Address <input type="checkbox"/> Signed [Signature] Date 8-3-76 Authorized representative	
18. Elevation:		19. Remarks: (Use a second sheet if needed)				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Minter-Wilson

CHUCK JAEGER
Kearny County
11-20-75

Location: SE 24-25-36
30 feet East of Pivot
Pivot 40

Static Water Level - 80'

0	1	Top Soil
1	13	Fine Sand
13	65	Med. Coarse Gravel (Loose)
65	91	Brown Sandy Clay
91	155	Med. Sand & Gravel
155	171	Blue Clay
171	214	Fine to Med. Sand & Gravel (Loose)
214	234	Brown Sandy Clay
234	244	Fine to Med. Sand & Gravel
244	306	Brown Sandy Clay
306	356	Fine to Med. Sand & Gravel
356	360	Fine to Med. Sand & Gravel mixed with Brown Rock
360	382	Brown Yellow Clay mixed With Brown Rock (Hard)
382	395	Shale

T.D. 360'