

| | | | | | | | |
|--|----|---|------|-----------------------|------------------------|--|--|
| 1 LOCATION OF WATER WELL: | | Fraction | | Section Number | Township Number | Range Number | |
| County: <u>Kearny</u> | | NW ¼ | NW ¼ | 18 | T 25 S | R 37 E/W | |
| Distance and direction from nearest town or city street address of well if located within city? From Kendall - 1 Mile South - 6 Miles SE on open Road, ¼ Mile North - East Side | | | | | | | |
| 2 WATER WELL OWNER: | | Triple T. Farms | | | | | |
| RR#, St. Address, Box # : | | P. O. Box 69 | | | | | |
| City, State, ZIP Code : | | Lakin, Kansas 67860 | | | | | |
| | | | | | | Board of Agriculture, Division of Water Resources Application Number: | |
| 3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: | | 4 DEPTH OF COMPLETED WELL: 280 ft. ELEVATION: | | | | | |
| <p>Diagram: A square divided into four quadrants labeled NW, NE, SW, SE. An 'X' is marked in the NW quadrant.</p> | | Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. | | | | | |
| | | WELL'S STATIC WATER LEVEL ... 58 ... ft. below land surface measured on mo/day/yr ... 8-6-94 | | | | | |
| | | Pump test data: Well water was ft. after hours pumping gpm | | | | | |
| | | Est. Yield gpm: Well water was ft. after hours pumping gpm | | | | | |
| | | Bore Hole Diameter 10-5/8 .in. to ... 280 ... ft., and in. to ft. | | | | | |
| | | WELL WATER TO BE USED AS: | | | | | |
| | | 5 Public water supply 8 Air conditioning 11 Injection well <input checked="" type="radio"/> Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes.....No..... <input checked="" type="checkbox"/> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <input checked="" type="checkbox"/> No | | | | | |
| 5 TYPE OF BLANK CASING USED: | | CASING JOINTS: Glued .. <input checked="" type="checkbox"/> Clamped .. | | | | | |
| 1 Steel 3 RMP (SR) | | Welded .. | | | | | |
| <input checked="" type="radio"/> PVC 4 ABS | | Threaded .. | | | | | |
| Blank casing diameter .. 5 in. to ... 100 ft., Dia .. 5 in. to ... 140 ft., Dia .. 5 in. to ... 240 ft. | | from 120 180 from 240 | | | | | |
| Casing height above land surface .. 12 in., weight 2.81 lbs./ft. Wall thickness or gauge No. 260 265 | | 140 220 260 | | | | | |
| TYPE OF SCREEN OR PERFORATION MATERIAL: | | 7 PVC | | | | | |
| 1 Steel 3 Stainless steel 5 Fiberglass | | 10 Asbestos-cement | | | | | |
| 2 Brass 4 Galvanized steel 6 Concrete tile | | 8 RMP (SR) 11 Other (specify) | | | | | |
| | | 9 ABS 12 None used (open hole) | | | | | |
| SCREEN OR PERFORATION OPENINGS ARE: | | 5 Gauzed wrapped <input checked="" type="radio"/> Saw cut 11 None (open hole) | | | | | |
| 1 Continuous slot 3 Mill slot 6 Wire wrapped | | 9 Drilled holes | | | | | |
| 2 Louvered shutter 4 Key punched 7 Torch cut | | 10 Other (specify) | | | | | |
| SCREEN-PERFORATED INTERVALS: | | From ... 100 ft. to ... 120 ft., From ... 140 ft. to ... 180 ft. | | | | | |
| | | From ... 220 ft. to ... 240 ft., From ... 260 ft. to ... 280 ft. | | | | | |
| GRAVEL PACK INTERVALS: | | From ... 92 ft. to ... 280 ft., From ft. to ft. | | | | | |
| | | From ft. to ft., From ft. to ft. | | | | | |
| 6 GROUT MATERIAL: | | 1 Neat cement <input checked="" type="radio"/> Cement grout <input checked="" type="radio"/> Bentonite 4 Other | | | | | |
| Grout Intervals: From ... 5 ft. to ... 25 ft., From ... 25 ft. to ... 92 ft., From ft. to ft. | | | | | | | |
| What is the nearest source of possible contamination: | | 10 Livestock pens 14 Abandoned water well | | | | | |
| 1 Septic tank 4 Lateral lines 7 Pit privy | | 11 Fuel storage 15 Oil well/Gas well | | | | | |
| 2 Sewer lines 5 Cess pool 8 Sewage lagoon | | 12 Fertilizer storage 16 Other (specify below) | | | | | |
| 3 Watertight sewer lines 6 Seepage pit 9 Feedyard | | 13 Insecticide storage NA | | | | | |
| Direction from well? | | How many feet? | | | | | |
| FROM | TO | LITHOLOGIC LOG | FROM | TO | PLUGGING INTERVALS | | |
| | | See attached log | | | | | |
| 7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <input checked="" type="radio"/> constructed, <input type="radio"/> reconstructed, or <input type="radio"/> plugged under my jurisdiction and was completed on (mo/day/year) ... 8-26-94 ... and this record is true to the best of my knowledge and belief. Kansas Water Contractor's License No. ... 208 ... This Water Well Record was completed on (mo/day/yr) ... 9-20-94 ... under the business name of Minter-Wilson Drilling Co., Inc. by (signature) <i>nora keller</i> | | | | | | | |
| INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records. | | | | | | | |

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Triple T Farms
Kearny County
8-6-94

Location: NW $\frac{1}{4}$ 18-25-37 -
Beaty Headquarters

Static Water Level - 58'

Test #1

0' to 6' - Top soil
6' to 25' - Shale
25' to 30' - Sand stone
30' to 32' - Shale
32' to 36' - Rusty sand
36' to 41' - Shale
41' to 69' - Sand stone with shale streaks
69' to 102' - Shale with streaks of sand stone
102' to 113' - Sand stone
113' to 124' - Shale
124' to 128' - Sand stone
128' to 134' - Shale
134' to 184' - Sand stone with shale streaks
184' to 211' - Shale with streaks of sand stone
211' to 274' - Sand stone with shale streaks
274' to 295' - Shale