WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

						Topeka, Nansas 00020
	County	Fraction		Section	number	Township number Range number
1. Location of well:	Hamilton	NE _{1/4} NE _{1/4}		27		T 25 S R 43
2. Distance and direction from nearest town or city from Hiway Jct. at Johnson well location it in city: 17 miles north 14 west, 2 north, 12 west 3. Owner R.R. or str. City, state				street:	bear creek rarms	
4. Locate with "X" in section below: Sketch map:					777711	6. Bore hole dia. 26 in. Completion date Well depth 432 ft. 5/30/79
NW NE E E E E E E E E E						7Cable toolXCotary Driven Dug Hollow rod Jetted Bored Reverse rotary
						8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other
5						9. Casing: Material Steel Height Above r below Threaded Welded Surface 18 in. RMP PVC Weight 36 _ 8 lbs./ft.
5. Type and color of material				From	То	Dia. 16in. to 291 st6 depth Wall Thickness: inches or Diain. to ft. depth gage No219
Surface				0	2	Lakewood
Soft brown clay				2	45	Slot/gauze 3/16" Length 140.6" Set between 291.6ft. and 432 ft.
Blue & brown clay				45	60	Gravel pack? X Size range of material 4 X 5/8
Gray & yellow clay			60	150	11. Static water level: 223 ft. below land surface Date 5/22/79	
Blue shale				150	170	1140 295 ft. after 14 hrs. pumping 1140 g.p.m.
Shale & rock very hard					265	ft. after hrs. pumping g.p.m. Estimated maximum yield 1500 g.p.m.
Shale w/small sandstone strips				265	285	13. Water sample submitted: mo./day/yr.
Shale & sa	ndstone medium	to tight	-	285	320	Yes x No Date 14. Well head completion: Pitless adapter 18 Inches above grade
Sandstone				320	328	15. Well grouted? X =
Shale & sandstone hard				328	341	
Shale & sa	ndstone		80%	341	370	16. Nearest source of possible contamination: ft Direction Typefield
Shale & sa	ndstone		60%	370	383	Well disinfected upon completion?YesXNo
Shale & sandstone medium to tight=small loose				s3 3 3	405	17. Pump: Not installed Manufacturer's name
Shale & red and brown sandstone 50%				405		Model number HP Volts Length of drop pipe ft. capacityg.p.m.
Shale & sandstone hard			428	435	Type: Submersible Turbine	
(Use a second sheet if needed)						Jet Reciprocating Other
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report
Тородгарну:						is true to the best of my knowledge and belief.
HillSlope						Houck Bros. Drlg. Co. 164 Busings game 187, Ulysses, Ks. License No. Address
Upland Valley						Signed N. Buard 8/22/79 Authorized representative