

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Sedgwick</u>		<u>SW 1/4 SW 1/4 SW 1/4</u>	<u>22</u>	<u>T 26 S</u>	<u>R 1 EW</u>
Distance and direction from nearest town or city street address of well if located within city? <u>See Below</u>					
2 WATER WELL OWNER: <u>Jim Baldwin</u>					
RR#, St. Address, Box #: <u>4650 N. Ridge Rd.</u>				Board of Agriculture, Division of Water Resources	
City, State, ZIP Code: <u>Wichita, KS 67205</u>				Application Number: <u>40</u>	
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>40</u> ft. ELEVATION: <u>8/12/95</u> ft.			
		Depth(s) Groundwater Encountered <u>13</u> ft. 2. <u>40</u> ft. 3. <u>40</u> ft.			
		WELL'S STATIC WATER LEVEL <u>13</u> ft. below land surface measured on mo/day/yr <u>8/12/95</u>			
		Pump test data: Well water was <u>30</u> ft. after <u>11</u> hours pumping <u>40</u> gpm			
		Est. Yield <u>30</u> gpm Well water was <u>40</u> ft. after <u>11</u> hours pumping <u>40</u> gpm			
		Bore Hole Diameter <u>11</u> in. to <u>40</u> ft. and <u>40</u> in. to <u>40</u> ft.			
		WELL WATER TO BE USED AS:			
		☒ 1 Domestic ☐ 3 Feedlot ☐ 6 Oil field water supply ☐ 9 Dewatering ☐ 12 Other (Specify below) ☐ 2 Irrigation ☐ 4 Industrial ☐ 7 Lawn and garden only ☐ 10 Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes <u>X</u> No <u>X</u> If yes, mo/day/yr sample was submitted <u>X</u>			
		Water Well Disinfected? Yes <u>X</u> No <u>X</u>			
5 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>X</u> Clamped <u>X</u>
<u>2 PVC</u>		<u>4 ABS</u>	6 Asbestos-Cement	9 Other (specify below)	Welded <u>X</u>
			7 Fiberglass		Threaded <u>X</u>
Blank casing diameter <u>5</u> in. to <u>33</u> ft. Dia <u>2.60</u> in. to <u>40</u> ft. Dia <u>1.60</u> in. to <u>40</u> ft.					
Casing height above land surface <u>12</u> in. weight <u>2.60</u> lbs./ft. Wall thickness or gauge No. <u>160 PSI</u>					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-cement
2 Brass		4 Galvanized steel	6 Concrete tile	9 ABS	11 Other (specify)
					12 None used (open hole)
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot		<u>3 Mill slot</u>	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes	
			7 Torch cut	10 Other (specify)	
SCREEN-PERFORATED INTERVALS:					
From <u>33</u> ft. to <u>40</u> ft.		From <u>40</u> ft. to <u>40</u> ft.			
From <u>40</u> ft. to <u>40</u> ft.		From <u>40</u> ft. to <u>40</u> ft.			
GRAVEL PACK INTERVALS:					
From <u>26</u> ft. to <u>40</u> ft.		From <u>40</u> ft. to <u>40</u> ft.			
6 GROUT MATERIAL:					
1 Neat cement		<u>2 Cement grout</u>	3 Bentonite	4 Other	
Grout Intervals: From <u>3</u> ft. to <u>15</u> ft.		From <u>15</u> ft. to <u>40</u> ft.			
What is the nearest source of possible contamination:					
<u>1 Septic tank</u>		4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines		5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines		6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? <u>Southwest</u>		How many feet? <u>100</u>			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	Top soil			
2	11	clay			
11	21	fine sand			
21	22	clay			
22	40	fine to med. sand			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1) constructed</u> (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>8/12/95</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>3/8</u> This Water Well Record was completed on (mo/day/year) <u>8/15/95</u> under the business name of <u>Weninger Drilling</u> by (signature) <u>Karrma Morrisey</u>					