

WATER WELL RECORD (WWC-5)

Constructed

KOLAR DOC ID 1643544 WELL ID _____

Original Record Correction Change in Well Use

LOCATION OF WATER WELL

Latitude	37.74148	Longitude	-97.47865	Section	31	Township	26	Range	1	<input type="checkbox"/> E <input checked="" type="checkbox"/> W	Fraction	SW ¼ NW ¼ SW ¼
Datum	WGS84	Elevation	1358	County	Sedgwick							

WATER WELL OWNER

Name	
Business	Robl Building Co
Address	5842 W 21st St. Wichita KS 67205
Well location	316Z 3210 N Judith Wichita, KS 67205
<input type="checkbox"/> at owner's address	

WELL WATER USE

Domestic Lawn/Garden

COMPLETION

Depth of completed well: 80 ft.
 Depth(s) groundwater encountered:
 (1) _____ ft.; (2) _____ ft.;
 (3) _____ ft.; (4) dry well

Static water level in well: 15 ft.
 measured below land surface on (mm/dd/yy): 04/20/2022
 measured above land surface on (mm/dd/yy): _____

NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: Watertight sewer lines
 Distance from well: 13 Direction from well: E
 Source description: _____
 Source: _____
 Distance from well: _____ Direction from well: _____
 Source description: _____
 No potential source of contamination within 100 feet.

CONSTRUCTION

Borehole interval: from <u>0</u> to <u>60</u> ft.	Borehole diameter: <u>10.5</u> in.
Casing height above land surface: <u>16</u> in. If casing height is less than 12 in. has a variance been approved?* <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No *variance not required for monitoring or environmental remediation wells	
Casing type: <u>ThermalPlastic</u>	
Blank casing interval: <u>0</u> ft. to <u>60</u> ft.	
Blank casing diameter: <u>5</u> in.	
Casing joints: <u>Glued</u>	
Weight: _____ lbs/ft.	
Wall thickness or gauge no.: <u>SDR-26</u>	
Blank casing interval: _____ ft. to _____ ft.	
Blank casing diameter: _____ in.	
Casing joints: _____	
Weight: _____ lbs/ft.	
Wall thickness or gauge no.: _____	
Grout interval: <u>3</u> ft. to <u>23</u> ft.	
Grout material: <u>Bentonite</u>	
Grout interval: _____ ft. to _____ ft.	
Grout material: _____	
Screen / perforation material: <u>PVC</u>	
Screen / perforation openings: <u>Mill slot</u>	
Screen / perforation intervals: From <u>40</u> ft. to <u>60</u> ft. Slot size _____ unit _____	
From _____ ft. to _____ ft. Slot size _____ unit _____	
Gravel pack intervals: Gravel pack not used: <input type="checkbox"/> Gravel size _____ in	
From <u>23</u> ft. to <u>60</u> ft.	
Gravel pack not used: <input type="checkbox"/> Gravel size _____ in	
From _____ ft. to _____ ft.	

Estimated yield: 20 gpm
 Water level was: _____ ft. after _____ hours
 pumping _____ gpm
 Pump installed? Yes No
 Water well disinfected? Yes No
 Date disinfected (mm/dd/yy): _____
 Aquifer, if known: _____

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.: _____
 KDHE / EPA Project Code: _____
 Site Name: _____
 KDHE UIC Class V Form Completed: Yes No
 County Permit: Yes No Permit ID: _____
 Lease Name & Well #: _____
 # of boreholes: _____ # of dewatering wells: _____

LITHOLOGIC LOG

FROM	TO	LITHOLOGY INTERVALS
0	2	topsoil
2	17	clay
17	20	sand, fine
20	30	sand, fine to medium
30	40	sand & gravel, medium
40	60	gravel, medium

COMMENTS

CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed reconstructed pursuant to the stated water well contractor's license and was completed on 04/20/2022. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on 05/20/2022 under the business name of Weninger Drilling, LLC, Kansas Water Well Contractor's License No. 884 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Travis Cutler

Send one copy to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.