

1 LOCATION OF WATER WELL
 County: Adair
 Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here ☐
3302 W Bayview

Fraction $\frac{1}{4}$ SW $\frac{1}{4}$ SW $\frac{1}{4}$ SW $\frac{1}{4}$

Section Number 24
 Township No. T 26 S
 Range Number R 1 E ☒ W

2 WATER WELL OWNER:
 RR#, Street Address, Box #: 3302 W Bayview
 City, State, ZIP Code : Wichita KS 67204

Global Positioning System (GPS) information:
 Latitude: (in decimal degrees)
 Longitude: (in decimal degrees)
 Elevation:
 Datum: ☐ WGS 84, ☐ NAD 83, ☐ NAD 27
 Collection Method:
☐ GPS unit (Make/Model:)
☐ Digital Map/Photo, ☐ Topographic Map, ☐ Land Survey
 Est. Accuracy: ☐ <3 m, ☐ 3-5 m, ☐ 5-15 m, ☐ >15 m

3 LOCATE WELL WITH AN "X" IN SECTION BOX:
 N
 W NW NE
SW SE E
 S
 [-----1 mile-----]

4 DEPTH OF COMPLETED WELL 36 ft.
 Depth(s) Groundwater Encountered (1).....16..... ft. (2)..... ft. (3)..... ft.
 WELL'S STATIC WATER LEVEL.....16.....ft. below land surface measured on mo/day/yr. 6-8-12
 Pump test data: Well water was.....ft. after..... hours pumping..... gpm
 EST. YIELD.....gpm Well water was.....ft. after..... hours pumping..... gpm
 Bore Hole Diameter9.....in. to 16.....ft., andin. toft.
 WELL WATER TO BE USED AS: ☐ Public water supply ☐ Geothermal ☐ Injection well
☐ Domestic ☐ Feedlot ☐ Oil field water supply ☐ Dewatering ☐ Other (Specify below)
☐ Irrigation ☐ Industrial ☒ Domestic-lawn & garden ☐ Monitoring well
 Was a chemical/bacteriological sample submitted to Department? ☐ Yes ☒ No
 If yes, mo/day/yr sample was submitted.....
 Water well disinfected? ☐ Yes ☒ No

5 TYPE OF CASING USED: ☐ Steel ☒ PVC ☐ Other
 CASING JOINTS: ☒ Glued ☐ Clamped ☐ Welded ☐ Threaded
 Casing diameter5..... in. to 36..... ft., Diameter in. to ft., Diameter in. to ft.
 Casing height above land surface.....12..... in., Weightlbs./ft., Wall thickness or gauge No. 160
 TYPE OF SCREEN OR PERFORATION MATERIAL:
☐ Steel ☐ Stainless Steel ☒ PVC ☐ Other (Specify)
☐ Brass ☐ Galvanized Steel ☐ None used (open hole)
 SCREEN OR PERFORATION OPENINGS ARE:
☐ Continuous slot ☒ Mill slot ☐ Gauze wrapped ☐ Torch cut ☐ Drilled holes ☐ None (open hole)
☐ Louvered shutter ☐ Key punched ☐ Wire wrapped ☐ Saw cut ☐ Other (specify)
 SCREEN-PERFORATED INTERVALS: From.....26..... ft. to36..... ft., From ft. to ft.
 GRAVEL PACK INTERVALS: From..... ft. to ft., From ft. to ft.
none

6 GROUT MATERIAL: ☐ Neat cement ☒ Cement grout ☐ Bentonite ☐ Other
 Grout Intervals: From0..... ft. to16..... ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination:
☐ Septic tank ☐ Lateral lines ☐ Pit privy ☐ Livestock pens ☐ Insecticide storage ☐ Other (specify below)
☐ Sewer lines ☐ Cesspool ☐ Sewage lagoon ☐ Fuel storage ☐ Abandoned water well
☒ Watertight sewer lines ☐ Seepage pit ☐ Feedyard ☐ Fertilizer storage ☐ Oil well/gas well
 Direction from well Distance from well12.....

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHO. LOG (cont.) or PLUGGING INTERVALS
<u>0</u>	<u>5</u>	<u>Top Soil</u>			
<u>5</u>	<u>18</u>	<u>Fine Tan Sand</u>			
<u>18</u>	<u>36</u>	<u>Coarse Tan Sand</u>			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was ☒ constructed, ☐ reconstructed, or ☐ plugged under my jurisdiction and was completed on (mo/day/year)6-8-12..... and this record is true to the best of my knowledge and belief.
 Kansas Water Well Contractor's License No.473..... This Water Well Record was completed on (mo/day/year)6-9-12.....
 under the business name of Beardley Pump & Well by (signature) David Reed

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks and check the correct answers. Send three copies (white, blue, pink) to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5524. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at <http://www.kdheks.gov/waterwell/index.html>.