


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 19	Township number T 26 S	Range number R 1W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 325 Heather Lane Maize, Kansas			3. Owner of well: Weidman Way Homes R.R. or street: 2100 South West Street City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N Sketch map:  W E S 1 Mile 1 Mile			6. Bore hole dia. 4 1/2 in. Completion date 9-21-77 Well depth 42 ft.		
5. Type and color of material			7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
			8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other		
			9. Casing: Material styrene Height: Above or below 1111 Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC 42 Weight 5 lbs./ft. Dia. 5 in. to 4 1/2 ft. depth Wall Thickness: inches or Dia. 5 in. to 4 1/2 ft. depth gage No. 200		
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot 1/16 in. .06 Length 10' Set between 32 ft. and 42 ft. ft. and 1/4-1/8" ft. Gravel pack? ☒ yes Size range of material 1/4-1/8"		
			11. Static water level: 15 ft. below land surface Date 9-21-77 mo./day/yr.		
(Use a second sheet if needed)			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____		
			14. Well head completion: _____ capped _____ Pitless adapter 12 inches above grade		
			15. Well grouted? ☒ yes 1-2 fine sand With: _____ Bentonite _____ Concrete Depth: From 6 ft. to 16 ft.		
			16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? ☒ Yes _____ No		
(Use a second sheet if needed)			17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
			18. Elevation:		
			19. Remarks: Septic system not installed at this time. No apparent source for contamination. Well will be in the basement.		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 12-4-77 Authorized representative		
			Topography: ☐ Hill ☒ Slope ☐ Upland ☐ Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5