

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction 1/4 NW 1/4 SE 1/4	Section number 1	Township number 26 T S R	Range number 1W E/W				
2. Distance and direction from nearest town or city: Street address of well location if in city: 3120 West 72nd St. No. Wichita, Kansas				3. Owner of well: Ruth Shaw R.R. or street: 107 North Meridian City, state, zip code: Valley Center, Kansas 67147						
4. Locate with "X" in section below: Sketch map: N 1 Mile W <table border="1" style="display: inline-table; vertical-align: middle;"><tr><td>NW</td><td>NE</td></tr><tr><td>SW</td><td>SE</td></tr></table> E S 1 Mile				NW	NE	SW	SE	6. Bore hole dia. 11 in. Completion date 1-5-78 Well depth 50 ft.		
NW	NE									
SW	SE									
5. Type and color of material				7. ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary						
				8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other						
				9. Casing: Material styrene height: Above or below surface 12 in. Threaded ☐ Welded ☒ gl Surface 12 in. RMP ☒ PVC ☐ Weight ☐ lbs./ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches 0.200 Dia. ☐ in. to ☐ ft. depth gage No. ☐						
				10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot size .06 Length 10' Set between 40 ft. and 50 ft. ft. and 1/4-1/8" ft. Gravel pack? yes Size range of material 1/4-1/8"						
				11. Static water level: 15 ft. below land surface Date 1-5-78 mo./day/yr.						
(Use a second sheet if needed)				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.						
				13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____						
				14. Well head completion: ☒ Pitless adapter 12 Inches above grade						
				15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.						
				16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? ☒ Yes ____ No						
(Use a second sheet if needed)				17. Pump: Not installed Manufacturer's name STA-RITE Model number 20P4D02 HP 3/4 Volts 230 Length of drop pipe 40 ft. capacity 50 g.p.m. Type: ☒ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other						
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. ____ Address ____ Signed Mary Arnold Date 4-11-78 Authorized representative						
				18. Elevation:						
				19. Remarks: Flat Ground Septic system not installed at this time.						
				Topography: ____ Hill ____ Slope ____ Upland ____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

No apparent source for contamination.