USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Sedgwick	1/4 SW 1/4 SW 1/4	2	T 26 S	R 1W E/W

2. Distance and direction from nearest town or city: 69th St. North & Hoover
Street address of well location if in city: Valley Center, Kansas

3. Owner of well: Claire Evans
R.R. or street: R # 1 Box 250
City, state, zip code: Valley Center, Kansas

4. Locate with "X" in section below: Sketch map:

N — NW — NE — W — E — SW — SE — S — X — 1 Mile — 1 Mile

6. Bore hole dia. 30 in. Completion date 4-18-79
Well depth 64 ft.

7. __ Cable tool __ Rotary __ Driven X Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: See #19 Material Transite Height: Above or below ////
Threaded ___ Welded ___ Surface 12 in.
RMP ___ PVC ___ Weight 37 lbs./ft.
Dia. 16 in. to 64 ft. depth Wall Thickness or gage No. 3/4"
Dia. ___ in. to ___ ft. depth

5. Type and color of material	From	To
Topsoil	0	1
Clay	1	5
Fine to Coarse Sand and Medium Gravel	5	15
Medium to Coarse Sand and Gravel	15	64
1		
(Use a second sheet if needed)		

10. Screen: Manufacturer's name Johnson
Type irrigator Dia. 16"
Slot/gauze .100 Length 33'
Set between 44 31 ft. and 44 64 ft.
___ ft. and ___ ft.
Gravel pack? yes Size range of material 1/4-1/8"

11. Static water level: 13 ft. below land surface Date mo./day/yr. 4-18-79

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
X Yes ___ No Date

14. Well head completion:
___ Pitless adapter 12 Inches above grade

15. Well grouted? yes 1-2 finesandmix
With: ___ Neat cement ___ Bentonite X Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: None
ft. ___ Direction ___ Type ___
Well disinfected upon completion? X Yes ___ No

17. Pump: ___ Not installed
Manufacturer's name Valley
Model number 12XLE-1-A HP 40 Volts ___
Length of drop pipe 50 ft. capacity 1500 g.p.m.
Type:
___ Submersible X Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

T 26 R 1 W Sec 2 1/4 1/4 1/4 1/4 SE

18. Elevation:
Topography:
___ Hill
___ Slope
___ Upland
___ Valley

19. Remarks: Flat Ground
From # 9 above- Branded But Joint

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Harp Well & Pump License No. 236
Address Wichita, Kansas
Signed M. Arnold Date 5-19-79
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023