


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction NW 1/4 NE 1/4 NW 1/4	Section number 5	Township number T 26 S R 1 E	Range number 1
2. Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: R.R. or street: City, state, zip code:		Robert Ulbrick R.R. 1 Valley Center, Kansas 67147		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 26 in. Completion date 7/30/77 Well depth 156 ft.		
5. Type and color of material		From		To		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Top soil to sandy clay		0		5		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Med. to coarse sand		5		50		9. Casing: Material Transite Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input checked="" type="checkbox"/> 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30 lbs./ft.
Fine to med. sand w/clay		50		60		Dia. 16 in. to 117 ft. depth Wall Thickness: inches or Dia. 8 in. to 117 ft. depth Gauge No. 3/16
fine sand and clay		60		75		10. Screen: Manufacturer's name Johnson
Brown sandy clay		75		90		Type sawed Dia. 16 Slot/gauze 3/16 Length 39 Set between 117 ft. and 156 ft. ft. and ft.
Med. to fine sand		90		95		Gravel pack? yes Size range of material 1/8-1/4
Med. to fine sand w/clay		95		100		11. Static water level: mo./day/yr. 13 ft. below land surface Date 7/30/77
Fine sand w/ clay		100		105		12. Pumping level below land surfaces: 49 ft. after 1 hrs. pumping 800 g.p.m. 68 ft. after 2 hrs. pumping 1400 g.p.m. Estimated maximum yield 2500 g.p.m.
Hard brown clay		105		110		13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
Fine sand w/clay		110		115		14. Well head completion: 8 Inches above grade <input type="checkbox"/> Pitless adapter
Fine to med. sand with clay		115		120		15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Med. sand w/little clay		120		130		16. Nearest source of possible contamination: ft. Direction none Type none Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Coarse sand w/clay		130		135		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roller Model number 2 stage 120H 80 Volts 80 Length of drop pipe 80 ft. capacity 1300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Med. to fine sand very little clay		145		150		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Darling Drilling Co. 189 Business name License No. Address 1211 W. 4th, Hutchinson, Kan Signed Darrell J. Darling Date 7/30/77 Authorized representative
Fine sand		150		155		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Fine sand to blue shale Bottom of well 156'				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5