

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Sedgwick	Township name Park	Fraction NE-NE-SE	Section number 19	Town number T-26-S	Range number R1W		
Distance and direction from nearest town or city: Street address of well location if in city: Same			3 Owner of well: Bretz, Dennie Address: 502 Queen, MAIZE, KS.					
Locote with "X" in section below: N W E S 1 Mile			Sketch map: E S Queen St.			4 Well depth: 41 ft. Date of completion 7-11-77 Well diameter 9 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Black dirt		0	3'	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
			clay & sand		3'	9'	7 Casing: Material RMP Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 13 in. Diam. glued Weight 200 lbs./ft. 6 in. to 31 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth	
			Sugar sand		9'	19'	8 Screen: Sunflower Manufacturer RMP Dia. 6 in. Type RMP Slot gauge .075 Length 2 in. Set between 31 ft. and 41 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material ___	
			water begins		18'		9 Static water level: 18 ft. below land surface Date 7-11-77	
			Con't. with sugar sand			25'	10 Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield ___ g.p.m.	
			coarse sand		25'	32'	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___	
Coarse sand - with some sugar sand		32'	35'	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade				
Coarse sand		35'	41'	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 2 ft. to 12 ft. (2-12)				
(use a second sheet if needed)				14 Nearest source of possible contamination: sewer ft. 25 Direction Se. Type line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer will put 4 ft. square 4 in thick cement pad at ground level.			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Whitchurch Well Serv. 309 Business name License No. Address 520 James MAIZE Signed W. Whitchurch 7-10-77 Authorized representative			

96 10 19 NE NE SE