


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Sedgwick</u>	Fraction <u>NE 1/4 NE 1/4 SE 1/4</u>	Section number <u>19</u>	Township number <u>T 26 S</u>	Range number <u>R 1 E</u>
2. Distance and direction from nearest town or city:		3. Owner of well: <u>Kathryn Barnett</u>		R.R. or street: <u>5431 Paula</u>		
Street address of well location if in city: <u>319 Jonathan Maize KS</u>		City, state, zip code: <u>Wichita KS 67212</u>				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole <u>1 1/2</u> in. Completion date <u>3/23/78</u>		
N 1 Mile W E S 1 Mile				Well depth <u>52</u> ft.		
5. Type and color of material		From		To		7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
Top soil		0		4		8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other
Red clay		4		18		9. Casing: Material <u>PVC</u> Height <u>Above</u> or below
fine sand		18		28		Threading <u>Welded</u> ☒ Surface <u>1 1/2</u> in.
Red clay		28		30		RMP <u>PVC</u> ☒ Weight <u>2.76</u> lbs./ft.
med. to coarse gravel		30		52		Dia. <u>5</u> in. to <u>52</u> ft. depth Wall Thickness: inches <u>1/2</u>
Red clay		52				Dia. <u>5</u> in. to <u>52</u> ft. depth gage No. <u>258</u>
						10. Screen: Manufacturer's name <u>M.P.I.</u>
						Type <u>Sch 40</u> Dia. <u>5</u> in.
						Not gauze <u>1 1/2</u> Length <u>10</u> ft.
						Set between <u>1 1/2</u> ft. and <u>5</u> ft.
						Gravel pack? <u>yes</u> size range of material <u>3/8</u>
						11. Static water level: <u>23</u> ft. below land surface Date <u>3/23/78</u>
						12. Pumping level below land surfaces:
						<u>24</u> ft. after <u>1/2</u> hrs. pumping <u>20</u> g.p.m.
						<u>24</u> ft. after <u>1/2</u> hrs. pumping <u>20</u> g.p.m.
						Estimated maximum yield <u>75</u> g.p.m.
						13. Water sample submitted: <u>Yes</u> ☒ No ☐ Date <u>3/23/78</u>
						14. Well head completion: <u>12</u> inches above grade
						☒ Pitless adapter <u>12</u> inches above grade
						15. Well grouted? <u>yes</u>
						With: <u>Neat cement</u> ☐ Bentonite ☒ Concrete ☐
						Depth: From <u>3</u> ft. to <u>13</u> ft.
						16. Nearest source of possible contamination: <u>None</u>
						ft. <u>None</u> Direction <u>None</u> Type <u>None</u>
						Well disinfected upon completion? ☒ Yes ☐ No
						17. Pump: <u>Not installed</u>
						Manufacturer's name <u>FFW</u>
						Model number <u>10518</u> HP <u>1/2</u> Vol. <u>220</u>
						Length of drop pipe <u>30</u> ft. capacity <u>10</u> g.p.m.
						Type: ☒ Submersible ☐ Turbine
						☐ Jet ☐ Reciprocating
						☐ Centrifugal ☐ Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: ☐ Hill ☒ Slope ☐ Upland ☐ Valley		Customer to furnish 4x4x4 slab around casing as per state regulations Signed <u>X Kathryn Barnett</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Whynne Bullock</u> 3/18 Business name <u>Sedgwick</u> License No. <u>1/4 1/4 1/4</u> Address <u>Sedgwick</u> Signed <u>Whynne Bullock</u> Date <u>3/29/78</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5