


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County PRATT Fraction NE 1/4 NE 1/4 SE 1/4 Section number 1 Township number T 26 S R 11 W Range number E/W	
2. Distance and direction from nearest town or city: 2 W of Taron, KS Street address of well location if in city: Taron, KS	
3. Owner of well: RON SCHWERTFEGER R.R. or street: City, state, zip code: Taron, KS	
4. Locate with "X" in section below: Sketch map: 	
6. Bore hole dia. 30 in. Completion date 30 Dec 78 Well depth 90 ft.	
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 50 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188	
5. Type and color of material	
10. Screen: Manufacturer's name WABrown & Cook Type _____ Dia. 16" Slot/gauze 1/8 Length 40' Set between 50-60 Cook ft. and _____ ft. 60 ft. and 90 Brown ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 X 3/8	
11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 30 Dec 78	
12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 800 g.p.m. 36 ft. after 1 hrs. pumping 900 g.p.m. Estimated maximum yield 1500 g.p.m.	
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: _____ Not installed Manufacturer's name BERKLEY Model number _____ HP _____ Volts _____ Length of drop pipe 80 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 5'X10'X8" Concrete slab poured at surface
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name _____ License No. _____ Address Box 1032 Pratt KS Signed J. Honomell Date 15 Jan 79 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5