

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: <u>Pratt</u>	Fraction: <u>NE 1/4 SW 1/4 NE 1/4</u>	Section number: <u>13</u>	Township number: <u>T 26 S R 11 W</u>	Range number: <u>E/W</u>
2. Distance and direction from nearest town or city: <u>2 W 15 of Turon, Ks</u>			3. Owner of well: <u>GENE GEGSLING</u>			
Street address of well location if in city: <u>Turon, Ks</u>			City, state, zip code: <u>TURON, KS</u>			
4. Locate with "X" in section below:		Sketch map: <u>Drainage</u>		6. Bore hole dia. <u>30</u> in. Completion date <u>21 July 78</u>		
				Well depth <u>90</u> ft.		
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
<u>Sod, Sandy</u>		<u>0</u>	<u>2</u>	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
<u>Clay, tan</u>		<u>2</u>	<u>17</u>	9. Casing: Material <u>SYL</u> Height <u>Above</u> or below <u>12</u> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>16</u> in. to <u>35</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>188</u>		
<u>Sand, fine to coarse & med gravel</u>		<u>17</u>	<u>30</u>	10. Screen: Manufacturer's name <u>WABrown & Cook</u> Type <input type="checkbox"/> Dia. <u>16"</u> Slot/gauze <u>1/8</u> Length <u>50'</u> Set between <u>35-55 BAN</u> and <u>70-90 BAN</u> <u>60-70 COOK</u> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 X 3/8</u>		
<u>Clay, white & gray</u>		<u>30</u>	<u>35</u>	11. Static water level: <u>17</u> ft. below land surface Date <u>21 July 78</u> mo./day/yr.		
<u>Sand, Fine to coarse & med gravel</u>		<u>35</u>	<u>48</u>	12. Pumping level below land surfaces: <u>41</u> ft. after <u>1</u> hrs. pumping <u>869</u> g.p.m. <u>29</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. Estimated maximum yield <u>1000</u> g.p.m.		
<u>Clay, tan & gray</u>		<u>48</u>	<u>60</u>	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
<u>Sand, fine to coarse & fine to med gravel</u>		<u>60</u>	<u>92</u>	14. Well head completion: Pitless adapter <u>12</u> inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>None</u> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: Not installed Manufacturer's name <u>Western Sand Kellers</u> Model number <input type="checkbox"/> HP <u>80</u> Volts <input type="checkbox"/> Length of drop pipe <u>80</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other <input type="checkbox"/>		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Central well & pump 325</u> Business name License No. Address <u>171 S. Taylor Pratt Ks</u> Signed <u>Stonovich</u> Date <u>1 Aug 78</u> Authorized representative		
18. Elevation:		19. Remarks: <u>5' X 16' Concrete slab poured at surface</u>				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

26
 11
 13
 NE 1/4 SW 1/4
 Sec 13

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5