

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County PRATT	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 26	Township number T 26 S R 11 W E(W)	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: R.R. or street: City, state, zip code:		6. Bore hole dia. <u>30</u> in. Completion date <u>28 APR 77</u> Well depth <u>92</u> ft.	
4. Locate with "X" in section below:		Sketch map:		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material <u>5/8" STL</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>4 1/2</u> in. to <u>52</u> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <u>188</u>	
<u>SOIL, SANDY</u>		<u>0</u>	<u>2</u>	10. Screen: Manufacturer's name <u>WA BROWN</u> Type <u>FRETLO</u> Dia. <input type="checkbox"/> Slot/gauze <u>1/8</u> Length <u>40'</u> Set between <u>52</u> ft. and <u>92</u> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.	
<u>CLAY, TAN & CALICHE</u>		<u>2</u>	<u>18</u>	Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/8 - 1/2</u>	
<u>SAND, FINE TO COARSE W/ CALICHE & CLAY STREAKS</u>		<u>18</u>	<u>48</u>	11. Static water level: <input type="checkbox"/> mo./day/yr. <u>24</u> ft. below land surface Date <u>28 APR 77</u>	
<u>SAND, FINE TO COARSE & MED GRAVEL (MED LOOSE)</u>		<u>48</u>	<u>62</u>	12. Pumping level below land surfaces: <u>60</u> ft. after <u>1</u> hrs. pumping <u>726</u> g.p.m. <u>50</u> ft. after <u>1</u> hrs. pumping <u>675</u> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
<u>SAND, VERY FINE TO COARSE & FINE GRAVEL</u>		<u>62</u>	<u>88</u>	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
<u>SLIGHTLY SILTY (MED LOOSE)</u>				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
<u>CLAY, GRAY</u>		<u>88</u>	<u>90</u>	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
<u>SAND, VERY FINE TO COARSE SAND</u>		<u>90</u>	<u>95</u>	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <u>NONE</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>CLAY, SANDY TAN</u>		<u>95</u>	<u>105</u>	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>FLOWAY</u> Model number <input type="checkbox"/> HP <u>80</u> Volts <input type="checkbox"/> Length of drop pipe <u>80</u> ft. capacity <u>700</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>CENTRAL WELL & PUMP 325</u> Business name License No. Address <u>121 S. TAYLOR PRATT</u> Signed <u>[Signature]</u> Date <u>28 APR 77</u> Authorized representative	
18. Elevation:	19. Remarks: <u>5' x 10' SLAB POURED AT SURFACE</u>		20. Water well contractor's certification: (continued)		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

26 T 26 S R 11 W E(W)
 Sec 26 NE 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5