


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction C N 1/2 1/4 1/4 1/4	Section number 8	Township number T 26 S R	Range number 12 E/W
2. Distance and direction from nearest town or city: 5 m. N. & 1/2 E. of Iuka Street address of well location if in city:			3. Owner of well: Fay Keller R.R. or street: Iuka, Kansas City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map: Well No. 2 (TH 2-77)		
5. Type and color of material			From	To	6. Bore hole dia. 30 in. Completion date 5/4/77 Well depth 120 ft.
Very sandy soil			0	2	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Clay			2	41	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Med. to co. sand & gravel			41	65	9. Casing: Material Stl. Height: Above <input type="checkbox"/> below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34.25 lbs./ft. Dia. 16 in. to 81 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 203
Sandy clay			65	80	10. Screen: Manufacturer's name Doerr Metal Products Type Steel Dia. 16 " Slot/gauze 1/8 " Length 40 ' Set between 80 ft. and 120 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 x 3/8
Med. to co. sand & gravel			80	125	11. Static water level: <input type="checkbox"/> mo./day/yr. 29 ft. below land surface Date 5/4/77
					12. Pumping level below land surfaces: 48 ft. after 4 hrs. pumping 100 ² g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1200 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 200 Direction West Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 12RL HP 80 Volts <input type="checkbox"/> Length of drop pipe 80 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name Layne Western Co. License No. <input type="checkbox"/> Address Wichita, Kansas Signed [Signature] Date 5/10/77 Authorized representative		

T 26
 R 12
 S W
 Sec 8
 C N 1/2

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5