

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction 1/4 NW 1/4 SW 1/4	Section number 4	Township number T 26 S R 13	Range number 13
2. Distance and direction from nearest town or city: 5 3/4 miles North of Iuka, KS Street address of well location if in city:				3. Owner of well: Don Weingartner R.R. or street: 16 Sunflower City, state, zip code: Hutchinson, KS 67501		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: 		
5. Type and color of material				From	To	6. Bore hole dia. <u>24</u> in. Completion date <u>5-31-78</u> Well depth <u>100</u> ft. Pump Set 7-7-78
Top soil				0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Brown Brown & gray clay				3	22	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sandy clay & sand				22	42	9. Casing: Material <u>steel</u> Height: <u>(Above)</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>30.3</u> lbs./ft. Dia. <u>16</u> in. to <u>50</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>7 ga.</u>
Sand & gravel				42	61	10. Screen: Manufacturer's name <u>W. A. Brown</u> Type <u>Double-slot</u> Dia. <u>16"</u> Slot gauge <u>1/8"</u> Length <u>50'</u> Set between <u>50</u> ft. and <u>100</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>Yes</u> Size range of material <u>3/8-200</u>
White & gray clay				61	68	11. Static water level: <u>17</u> ft. below land surface Date <u>5-31-78</u> mo./day/yr.
Sand & gravel				68	99	12. Pumping level below land surfaces: NOT CHECKED <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.
Gray clay				99	100	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>
						14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
						15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
						16. Nearest source of possible contamination: <u>FIELD</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless Pump Co.</u> Model number <u>12LB-2</u> HP <u>80</u> Volts <u> </u> Length of drop pipe <u>70</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. <u> </u> Address <u>Great Bend, KS 67530</u> Signed <u>D.W. Clarke</u> Date <u>7-11-78</u> Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 26 S R 13 E 4
 Sec 4
 1/4 1/4 1/4
 NW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5