


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Snyder #1

1. Location of well:	County PRATT <i>Stafford</i>	Fraction NW 1/4 NE 1/4 W 1/4	Section number 8	Township number T 26	Range number S R 13	E/W
2. Distance and direction from nearest town or city: <i>1 1/2 west</i> Street address of well location if in city:	3. Owner of well: Duke Delo R.R. or street: 1105 William City, state, zip code: Great Bend, Ks 67530					
4. Locate with "X" in section below: N W E S 1 Mile	Sketch map: 		6. Bore hole dia. 9 in. Completion date 2-24-79 Well depth 77 ft.			
5. Type and color of material			From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 278.3 lbs./ft. Dia. 5 in. to 77 ft. depth Wall Thickness: <input type="checkbox"/> in. <input type="checkbox"/> or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200, 265	
					10. Screen: Manufacturer's name Peerless Type SAW Dia. 5 Slot/gauze 1/8 Length 20 Set between 77 ft. and 57 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/4	
					11. Static water level: 25 ft. below land surface Date 2-24-79 mo./day/yr.	
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8 ft. to 10 ft.			
			16. Nearest source of possible contamination: None ft. ____ Direction ____ Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Myers Water Well 113 Business name License No. ____ Address Great Bend, Ks 67530 Signed Clayton Bound Date 2-24-79 Authorized representative			

T 26
 R 13
 W 1/4
 E 1/4
 NW
 NE
 SW
 SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5