

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: Pratt		SW ¼ NW ¼ NW ¼	15	T 26 S	R 13 EW
Distance and direction from nearest town or city? Approx. 3½ miles North of Iuka, KS			Street address of well if located within city?		
2 WATER WELL OWNER:		Phil Shrack			
RR#, St. Address, Box # :		Board of Agriculture, Division of Water Resources			
City, State, ZIP Code :		Iuka, KS 67066 Application Number: Not Required			
3 DEPTH OF COMPLETED WELL 9 56 ft. Bore Hole Diameter 5 in. to 56 ft., and in. to ft.					
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well <u>Stock</u>			
Well's static water level 25 ft. below land surface measured on 10 month 3 day 1979 year					
Pump Test Data : Well water was ft. after hours pumping. gpm					
Est. Yield Not Checked gpm: Well water was ft. after hours pumping. gpm					
4 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)	5 Wrought iron	8 Concrete tile	Casing Joints: Glued Clamped
2 PVC		4 ABS	6 Asbestos-Cement	9 Other (specify below)	<u>Welded Solvent XX weld</u>
Blank casing dia 5 in. to 46 ft., Dia		7 Fiberglass	<u>Styrene 200</u> Threaded.		
Casing height above land surface 12 in., weight 1.5 lbs./ft. Wall thickness or gauge No. 200					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel	5 Fiberglass	8 RMP (SR)	11 Other (specify) <u>Styrene 200</u>
2 Brass		4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)
Screen or Perforation Openings Are:					
1 Continuous slot		3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter		4 Key punched	6 Wire wrapped	9 Drilled holes	
Screen-Perforation Dia 5 in. to 56 ft., Dia in. to ft., Dia in. to ft.					
Screen-Perforated Intervals: From 46 ft. to 56 ft., From ft. to ft. to ft.					
Gravel Pack Intervals: From 40 ft. to 56 ft., From ft. to ft. to ft.					
5 GROUT MATERIAL:					
1 Neat cement		2 Cement grout	3 Bentonite	4 Other	
Grouted Intervals: From 0 ft. to 10 ft., From ft. to ft. to ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Cess pool	7 Sewage lagoon	10 Fuel storage	14 Abandoned water well
2 Sewer lines		5 Seepage pit	8 Feed yard	11 Fertilizer storage	15 Oil well/Gas well
3 Lateral lines		6 Pit privy	9 Livestock pens	12 Insecticide storage	16 Other (specify below)
Direction from well <u>Southeast</u> How many feet <u>60</u> ? Water Well Disinfected? Yes <u>XX</u> No					
Was a chemical/bacteriological sample submitted to Department? Yes No <u>XX</u> If yes, date sample submitted month day year Pump Installed? Yes <u>XX</u> No					
If Yes: Pump Manufacturer's name <u>Berkeley Pump Co.</u> Model No. <u>4AM-11</u> HP <u>½</u> Volts <u>230</u>					
Depth of Pump Intake <u>42</u> ft. Pumps Capacity rated at <u>15</u> gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) <u>constructed</u> , (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 10 month 3 day 1979 year					
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>185</u>					
This Water Well Record was completed on 10 month 30 day 1979 year under the business name of <u>Clarke Well & Eq., Inc.</u> by (signature) <u>Darrell Clarke</u> (Darrell Clarke)					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG	
		0 7 Fine Sand			
		7 30 Clay - Sandy brown, gray			
		30 43 Sand & gravel - Med to Fine			
		43 44 Brown sandy clay			
		44 56 Sand & gravel - Medium			
ELEVATION: Unknown					
Depth(s) Groundwater Encountered 1. 25 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)					

OFFICE USE ONLY

T

26

R

13

E

SEC.

15

SW ¼

NW ¼

NE ¼

SE ¼