

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction SW 1/4 C-SW 1/4 1/4	Section number 24	Township number T 26 S	Range number R 13 E/W
2. Distance and direction from nearest town or city: 2 1/2 miles N & 2 miles E. of Iuka, Kansas Street address of well location if in city:			3. Owner of well: Ross Hoener Iuka, Kansas City, state, zip code: 67066			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: Well No. 2 (TH 1-74)		6. Bore hole dia. 30 in. Completion date _____ Well depth 160 ft. 7/2/76	
5. Type and color of material			From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Soil					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown clay					9. Casing: Material Stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 6 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.91 lbs./ft. Dia. 16 in. to 107 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 219	
Brown clay w/sand streaks					10. Screen: Manufacturer's name Doerr Metal Products	
Med. to coarse sand & gravel					Type Stl Dia. 16 " Slot/gauze 1/8 " Length 56 ' Set between 104 ft. and 160 ft. _____ ft. and _____ ft.	
Brown clay					Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/4 to 1/2	
Med. to coarse sand & gravel w/some clay lenses					11. Static water level: _____ mo./day/yr. 45.02 ft. below land surface Date 7/16/76	
					12. Pumping level below land surfaces: 72.0 ft. after 2 hrs. pumping 1150 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1500 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
					14. Well head completion: Pump Head & Seal <input type="checkbox"/> Pitless adapter 6 inches above grade	
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination ft. 1400 Direction SE Type Farm Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: _____ Not installed Manufacturer's name Layne & Bowler Model number 77191111 HP 75 Volts 460 Length of drop pipe 100 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					(Use a second sheet if needed)	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name: _____ License No. _____ Address Wichita, Kansas Signed [Signature] Date 6/19/76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5