

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction Center of 1/4 south 2 NW 1/4	Section number 4	Township number T 26 S R 14	Range number EW		
2. Distance and direction from nearest town or city: 1 1/2 Miles North of Byers, KS Street address of well location if in city:			3. Owner of well: Dwight Ellis R.R. or street: City, state, zip code: Byers, KS 67021				
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: APPROX. 1320 East and 2600 South of NW Corner of Sec. 4		6. Bore hole dia. 24 in. Completion date 4-9-79 Well depth 146 ft. Pump Set 5-2-79			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		Top soil		0	1	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		Gray clay		1	9	9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft. Dia. 16 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7 ga.	
		Brown & gray clay & limestone		9	34	10. Screen: Manufacturer's name W. A. Brown Type Double-slot Dia. 16" <input checked="" type="checkbox"/> Slot gauze 1/8" Length 46' Set between 100 ft. and 146 ft. Gravel pack? Yes Size range of material 3/8-200	
		Sand & gravel		34	51	11. Static water level: <input type="checkbox"/> mo./day/yr. 22' 6" ft. below land surface Date 4-9-79	
		Brown & gray clay		51	60	12. Pumping level below land surfaces: N/C <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
		Sand & gravel		60	71	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
		Brown & gray clay & limestone		71	87	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
		Sand & gravel		87	92	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
		Gray clay & limestone		92	97	16. Nearest source of possible contamination: FIELD ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(Use a second sheet if needed)				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless Pump Co. Model number 12LB-3 HP 80 Volts --- Length of drop pipe 70 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name Great Bend, KS 67530 License No. Address 5-3-79 Signed [Signature] Date 5-3-79 Authorized representative			
18. Elevation:	19. Remarks:						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

26
 146
 4
 CS NW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5