


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

17

1. Location of well:	County Pratt	Fraction Block 23 Lot 1/4 NE NE NE	Section number Byers Kansas	Township number 26	Range number 14 NW
2. Distance and direction from nearest town or city:	Street address of well location if in city: Byers Kansas		3. Owner of well: L & W Repair R.R. or street: City, state, zip code: Byers, Kansas		
<input checked="" type="checkbox"/> Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 5 1/2 in. Completion date 6-29-79 Well depth 80 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material _____ Height: 92 or below Threaded _____ Welded _____ Surface _____ in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 200	
5. Type and color of material		From To		10. Screen manufacturer's name Sunflower Plastics	
Top Soil		0 4		Type RMP Dia. 5 1/2	
Black Clay		4 7		Slot/gauze 1/8 Length 20	
Gray Clay		7 29		Set between 60 ft. and 80 ft.	
Sand & Rock		29 31		Gravel pack? <input checked="" type="checkbox"/> Size range of material 8x3/4	
Tan Clay		31 62		11. Static water level: _____ mo./day/yr. 26 ft. below land surface Date 6-29-79	
Gravel		62 80		12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 9 ft. to 14 ft.	
				16. Nearest source of possible contamination: ft. 80 Direction W Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name F & W Model number 789 12 HP 3/4 Vol 330 Length of drop pipe 42 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Mayo Water Well Serv. 224 Business name _____ License No. _____ Address _____ Signed Carl Mayo Date 6-29-79 Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

26
14
14
1/4
1/4
NE NE NE