

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 16	Township number T 26 S R 14 W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Stanley Mellgren R.R. or street: City, state, zip code: Byers, Ka			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 12 July 77 Well depth 80 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Soil		0	2	9. Casing: Material _____ Height: (A) Above or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200		
Clay, Brown		2	5	10. Screen: Manufacturer's name _____ 142 Type _____ Dia. 5 Slot/gauze 1/8" sewed Length 20' Set between 60 ft. and 80 ft. _____ ft. and _____ ft.		
Clay, sandy tan		5	21	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8" X 1/4"		
Sand, fine		21	25	11. Static water level: _____ mo./day/yr. 21 ft. below land surface Date 12 July 77		
Clay, Sandy brown		28	40	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.		
Sand, fine to med		40	46	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Clay, white		46	63	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Sand, coarse & med to coarse gravel-lens		63	80	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 4 ft. to 14 ft.		
Clay, white		80	90	16. Nearest source of possible contamination: ft. 300 Direction NW Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & pump 325 Business name _____ License No. _____ Address 121 S Taylor Pratt Signed J. Honowick Date 12 July 77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		4'x4'x4" slab at bottom of pit adapter				

T 26 S R 14 W E/W Sec 16 NW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5