

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Pratt Fraction SE 1/4 Rail Road Rightway Section number 16 Township number T 26 S Range number R 14 <input checked="" type="checkbox"/> NW																													
2. Distance and direction from nearest town or city: 500' W 100' N. of S.E. City Street address of well location in city: LIMIT BYERS Kansas 3. Owner of well: Leroy Hatzenbuehler R.R. or street: Byers, Kansas City, state, zip code: Byers, Kansas																													
<input checked="" type="checkbox"/> Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center; margin-top: 10px;"> <div style="text-align: center; margin-right: 20px;"> <p>1 Mile</p> <p>1 Mile</p> </div> </div>		6. Bore hole dia. 8 3/4 in. Completion date 6-30-79 Well depth 80 ft.																											
5. Type and color of material		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																											
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr><td>Top Soil</td><td>0</td><td>2</td></tr> <tr><td>Bl. Clay</td><td>2</td><td>7</td></tr> <tr><td>White Clay</td><td>7</td><td>33</td></tr> <tr><td>Gravel</td><td>33</td><td>35</td></tr> <tr><td>White & Tan Clay</td><td>35</td><td>50</td></tr> <tr><td>Brown Clay</td><td>50</td><td>58</td></tr> <tr><td>Gravel</td><td>58</td><td>77</td></tr> <tr><td>BR. Clay</td><td>77</td><td>80</td></tr> </tbody> </table>			From	To	Top Soil	0	2	Bl. Clay	2	7	White Clay	7	33	Gravel	33	35	White & Tan Clay	35	50	Brown Clay	50	58	Gravel	58	77	BR. Clay	77	80	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
	From	To																											
Top Soil	0	2																											
Bl. Clay	2	7																											
White Clay	7	33																											
Gravel	33	35																											
White & Tan Clay	35	50																											
Brown Clay	50	58																											
Gravel	58	77																											
BR. Clay	77	80																											
		9. Casing: Material _____ Weight: Above or below Threading: <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200																											
		10. Screen: Manufacturer's name Sunflower Plastics Type RMP Dia. 5 7/8 Slot gauze 8 Length 30 Set between 60 ft. and 80 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 5-24																											
		11. Static water level: _____ mo./day/yr. 28 ft. below land surface Date 6-30-79																											
		12. Pumping level below land surfaces: NO TEST hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.																											
		13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____																											
		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade																											
		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																											
		16. Nearest source of possible contamination: ft. 80 Direction NW Type Horse Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																											
		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																											
18. Elevation:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hayes Water Well Dr. 224 Business name 603 So. Maple, Byers, Kan License No. _____ Signed Carl Hayes Date 6-30-79 Authorized representative																											
19. Remarks: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																													

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5