


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Pratt</b>	Fraction <b>SE 1/4 NW 1/4 SE 1/4</b>	Section number <b>20</b>	Township number <b>T 26 S</b>	Range number <b>R 14 W E/W</b>
2. Distance and direction from nearest town or city: <b>1 1/2 of Byers</b>			3. Owner of well: <b>Royal Beck</b> R.R. or street: City, state, zip code: <b>Byers, Ka</b>			
4. Locate with "X" in section below: <div style="text-align: center;">  </div>			6. Bore hole dia. <b>30</b> in. Completion date _____ Well depth <b>126</b> ft. <b>18 Apr 78</b>			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Soil			9. Casing: Material <b>STL</b> Height: <b>above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <b>16</b> in. to <b>63</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>188</b>			
			10. Screen: Manufacturer's name <b>Amurlo</b> Type _____ Dia. <b>16"</b> Slot/gauze <b>1/8</b> Length <b>40'</b> Set between <b>63-83</b> ft. and <b>100-105</b> ft. <b>111</b> ft. and <b>126</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4 X 1/2</b>			
Sand, fine			From	To	11. Static water level: _____ mo./day/yr. <b>26</b> ft. below land surface Date <b>18 Apr 78</b>	
Sand, fine			0	2	12. Pumping level below land surfaces: <b>39</b> ft. after <b>1</b> hrs. pumping <b>800</b> g.p.m. <b>44</b> ft. after <b>1</b> hrs. pumping <b>1350</b> g.p.m. Estimated maximum yield <b>1600</b> g.p.m.	
<del>Clay, brown and red with sand streaks</del>			15	50	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sand, fine to coarse and fine gravel			50	53	14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade	
Clay, tan and white			53	62	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
<del>Sand, fine to coarse and med. to coarse gravel</del>			62	83	16. Nearest source of possible contamination: ft. _____ Direction _____ Type <b>None</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<del>Clay, green and tan</del>			83	90	17. Pump: _____ Not installed Manufacturer's name <b>Peerless</b> Model number _____ HP <b>80</b> Volts _____ Length of drop pipe <b>80</b> ft. capacity <b>800</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
<del>Clay, tan and white</del>			90	98	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Central Well &amp; Pump Svc. 325</b> Business name License No. Address <b>121 S. Taylor Pratt, Ks.</b> Signed <b>Bob Kormanick</b> Date <b>20 July 78</b> Authorized representative	
<del>Sand, fine to coarse and fine to coarse gravel</del>			98	105		
<del>Clay, green and tan</del>			105	111		
Sand, fine to coarse and fine to med. gravel			111	126		
<del>Clay, tan and caliche, hard</del>			126	145		
<del>Sand, very fine to med. silty</del>			145	160		
<del>Clay, red and yellow, sandy</del>			160	172		
Sand, fine to coarse			172	174		
<del>Clay, red, tan and green clay</del>			174	196		
18. Elevation:		19. Remarks: <b>6' X 12' X 8" slab was poured at surface</b>				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5