

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction 1/4 1/4 CSE 1/4	Section number 21	Township number T 26 S R	Range number 14 EW
2. Distance and direction from nearest town or city: 2 1/2 mi. Southeast of Byers, Kansas Street address of well location if in city:				3. Owner of well: N. L. Swinson R.R. or street: 8130 E. Skelly Drive City, state, zip code: Tulsa, Oklahoma 74129		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 24 in. Completion date 9-10-75 Well depth 160 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top soil		0	3	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy brown clay		3	14	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30 lbs./ft. Dia. 16 in. to 60 ft. depth Wall Thickness: inches or Dia. 16 in. to 140 ft. depth gage No. 7 ga.		
Gray & green clay & limestone		14	28	10. Screen: Manufacturer's name W. A. Brown Type Double-slot Dia. 16" Slot/gauze 1/8 Length 60' Set between 60 ft. and 100 ft. 140 ft. and 160 ft. Gravel pack? Yes Size range of material 3/8-200		
Sand & gravel		28	31	11. Static water level: 25 ft. below land surface Date 9-10-75 mo./day/yr.		
Brown & yellow clay & limestone		31	57	12. Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Sand, gravel & thin clay streak at 67'		57	71	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
Gray & brown clay & limestone		71	85	14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter		
Sand & gravel		85	98	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Brown & gray clay & limestone		98	133	16. Nearest source of possible contamination: NONE KNOWN ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Sandy clay & gravel streaks		133	147	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Dakota drift & clay streaks		147	158	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS Signed [Signature] Date 9-10-75 Authorized representative		
Dakota clay		158	160			
(Use a second sheet if needed)						
18. Elevation: 1995 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 24640 26 14 21 NDX				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5