

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Pratt</u>	Fraction <u>SW</u> 1/4 1/4 1/4	Section number <u>21</u>	Township number <u>26</u> T S R	Range number <u>14</u> E/W
2. Distance and direction from nearest town or city: <u>2.5 of Buys</u> Street address of well location if in city:			3. Owner of well: <u>Oren Berry</u> R.R. or street: <u>RL 3</u> City, state, zip code: <u>Pratt, Ks.</u>			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. <u>2 1/2</u> in. Completion date <u>9-23-75</u> Well depth <u>175</u> ft. 7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <u>Steel</u> Height <u>Above</u> or <u>below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>1 1/2</u> in. to <u>1 1/2</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <u>7</u>			
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>Danco</u> Type <u>steel</u> Dia. <u>1 1/2</u> Slot gauge <u>3/16</u> Length <u>80</u> Set between <u>75</u> ft. and <u>80</u> ft. <u>135</u> ft. and <u>175</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 3/4 3/8</u>	
<u>Sandy Top Soil</u>			<u>0</u>	<u>2</u>	11. Static water level: <u>20</u> ft. below land surface Date <u>9-14-75</u>	
<u>Gray Clay</u>			<u>2</u>	<u>11</u>	12. Pumping level below land surfaces: <u>18</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.	
<u>Fine Sand & Sandy Gray & Brown Clay</u>			<u>11</u>	<u>30</u>	13. Water sample submitted: <u> </u> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>9-17-75</u>	
<u>Sand & Gravel clean Coarse loose</u>			<u>30</u>	<u>40</u>	14. Well head completion: <u> </u> Pitless adapter <u> </u> Inches above grade	
<u>Gray Clay</u>			<u>40</u>	<u>50</u>	15. Well grouted? <input checked="" type="checkbox"/> With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
<u>Brown Clay</u>			<u>50</u>	<u>62</u>	16. Nearest source of possible contamination: ft. <u>1/4</u> Direction <u>W</u> Type <u>septic tank</u> Well disinfected upon completion? <u> </u> Yes <u> </u> No	
<u>Sand & Gravel clean Coarse loose</u>			<u>62</u>	<u>89</u>	17. Pump: <u> </u> Not installed Manufacturer's name <u>WLR</u> Model number <u>3CHG12</u> HP <u>40</u> Volts <u> </u> Length of drop pipe <u>70</u> ft. capacity <u>1200</u> g.p.m. Type: <u> </u> Submersible <input checked="" type="checkbox"/> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other	
<u>Brown Clay</u>			<u>89</u>	<u>91</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosecrantz - Bemis</u> <u>134</u> Business name License No. Address <u>Great Bend, Ks.</u> Signed <u>Fredia Gordon</u> Date <u>9/27/75</u> Authorized representative	
<u>Sand & Gravel clean Coarse loose</u>			<u>91</u>	<u>109</u>		
<u>Brown & white clay</u>			<u>109</u>	<u>130</u>		
<u>Sandy Brown Clay & Sand streaks</u>			<u>130</u>	<u>135</u>		
<u>Brown & Gray Clay</u>			<u>135</u>	<u>150</u>		
<u>Sand & Gravel clean Coarse loose</u>			<u>150</u>	<u>179</u>		
<u>Brown Clay</u>			<u>179</u>	<u>181</u>		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <u> </u> Hill <u> </u> Slope <input checked="" type="checkbox"/> Upland <u> </u> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5