

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: <u>Pratt</u>	Fraction: <u>SE 1/4 SW 1/4 SE 1/4</u>	Section number: <u>35</u>	Township number: <u>T 26 S</u>	Range number: <u>R 14 W E/W</u>
2. Distance and direction from nearest town or city: <u>4 1/4 W of Tuka, Ks</u>			3. Owner of well: <u>FAYE McMANNIS</u>			
Street address of well location if in city:			R.R. or street:			
			City, state, zip code: <u>Tuka, Ks</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>26 APR 78</u>		
				Well depth <u>120</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> Height: <u>above</u> or below		
				Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in.		
				RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
				Dia. <u>5</u> in. to <u>100</u> ft. depth Wall Thickness: inches or		
				Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>1258</u>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name		
Soil		0	3	<u>pebbles</u>		
Sand, fine		3	8	Type <u>saw slot</u> Dia. <u>5"</u>		
Clay, tan and white		8	36	Slot/gauze <u>1/8</u> Length <u>20'</u>		
Sand, fine to medium		36	55	Set between <u>100</u> ft. and <u>120</u> ft.		
Clay, tan and white		55	62	ft. and <input type="checkbox"/> ft.		
Sand, fine to coarse and med. gravel		62	87	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 X 1/2</u>		
Clay, tan and white		87	99	11. Static water level: <u>34.5</u> ft. below land surface Date <u>26 APR 78</u>		
Sand, coarse and gravel		99	111	12. Pumping level below land surfaces:		
Clay, tan		111	114	<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.		
Sand, fine to coarse and med. gravel		114	120	<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.		
				Estimated maximum yield <u>50</u> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From <u>4</u> ft. to <u>14</u> ft.		
				16. Nearest source of possible contamination: ft. <u>90</u> Direction <u>SE</u> Type <u>Septic</u>		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed		
				Manufacturer's name <u>STARITE</u>		
				Model number <u>20</u> HP <u>1</u> Volts <u>230</u>		
				Length of drop pipe <u>100</u> ft. capacity <u>25</u> g.p.m.		
				Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:		<u>4' x 4' x 4" slab poured below pitless adapter</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Hill				Central Well & Pump Svc. <u>325</u>		
<input type="checkbox"/> Slope				Business name License No.		
<input checked="" type="checkbox"/> Upland				Address <u>121 S. Taylor Pratt, Ks.</u>		
<input type="checkbox"/> Valley				Signed <u>St. Thomason</u> Date <u>29 APR 78</u>		
				Authorized representative		

2-6
 1-4
 3-5
 SE SW SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5