

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 36	Township number T 26 S	Range number R 14 W E/W
2. Distance and direction from nearest town or city: 6 N & 4 W OF PRATT		3. Owner of well: Jim McMannis		R.R. or street: Rt 4		
Street address of well location if in city:		City, state, zip code: Pratt, Kansas				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 1 AUG 79		
				Well depth 93 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material _____ Height Above or below Threaded _____ Welded _____ Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 73 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200		
5. Type and color of material		From	To	10. Screen: Manufacturer's name MODERN - F&W Supply		
Sandy soil		0	2	Type SLOT Dia. 5"		
Clay, tan and clay		2	23	Slot/gauze 1/6 Length 20'		
Tan clay		23	52	Set between 73 ft. and 93 ft. ft. and _____ ft.		
Sand, fine to coarse and medium gravel		52	64	Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/8 x 3/16		
Clay, tan and white		64	69	11. Static water level: _____ mo./day/yr. 47 ft. below land surface Date 1 AUG 79		
Sand, fine to coarse and coarse gravel		69	93	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 80 g.p.m.		
Clay, white		93	112	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sand, fine to coarse		112	122	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Sand, fine to coarse and medium gravel		122	145	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
				16. Nearest source of possible contamination: ft. 110 Direction SW Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name FOUR BANKS MORGAN Model number 1009 HP 1 Volts 220 Length of drop pipe 70 ft. capacity 25 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump, Inc. 325 Business name _____ License No. _____ Address P.O. Box 1032 PRATT, KS Signed J. Honovich Date SEPT 79 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		4' x 4' x 4" concrete slab poured below pitless adapter				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5