


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction nw 1/4 SW 1/4 se 1/4	Section number 7	Township number T 26 S R 15W E/W	Range number 15W E/W					
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Union Drlg Co K Inc R.R. or street: 505 Union Ctr City, state, zip code: Wichita, Ks. 67202								
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			6. Bore hole dia. 8 in. Completion date _____ Well depth 77 ft. 3-13-78					
5. Type and color of material			From			To					
			Top Soil-Clay			0			30		
			Sand			30			50		
			Sand-Gravel			50			77		
						7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other					
						9. Casing: Material _____ Height: Above or Below _____ Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 77 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gauge No. sub 40					
						10. Screen: Manufacturer's name _____ Jetstream Type PVC Dia. 5" Slot/gauze 1/32" Length 20' Set between 57 ft. and 77 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"					
						11. Static water level: _____ mo./day/yr. 22 ft. below land surface Date 3-13-78					
						12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.					
						13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____					
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade					
						15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
						16. Nearest source of possible contamination: oil ft. 75 Direction se Type test Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>					
						17. Pump: _____ Not installed Manufacturer's name GouIds Model number utm HP 3 Volts 230 Length of drop pipe 50 ft. capacity 50 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
			(Use a second sheet if needed)								
18. Elevation:		19. Remarks:					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name _____ License No. _____ Address R2 Great Bend, Ks. Signed Kelly Price Date 9-11-78 Authorized representative				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley											

2 to 1500 - 7
 WWS USE
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5