

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Pratt</b>	Fraction <b>C/NW</b> 1/4 1/4 1/4	Section number <b>12</b>	Township number <b>T 26 S R 15 E/W</b>	Range number
2. Distance and direction from nearest town or city: <b>4 1/4 East of Hopewell.</b>			3. Owner of well: <b>Jr. Grizzell</b> R.R. or street: City, state, zip code: <b>MACKSVILLE, KS</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>2 1/2</b> in. Completion date _____ Well depth <b>188</b> ft. <b>4-22-75</b>		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy Top Soil		0	2	9. Casing: Material <b>Steel</b> Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>18</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <b>16</b> in. to <b>18 1/2</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>7</b>		
Brown Clay		2	6	10. Screen: Manufacturer's name _____ Type <b>steel</b> Dia. <b>16</b> <del>Slot</del> <b>3/16</b> Length <b>60</b> Set between <b>128</b> ft. and <b>188</b> ft. _____ ft. and _____ ft. Gravel pack? <input type="checkbox"/> Size range of material <b>1/2 3/4 3/8</b>		
Rusty Brown Clay & Fine Sand		6	11	11. Static water level: _____ mo./day/yr. <b>18</b> ft. below land surface Date <b>11-5-74</b>		
Sandy Brown Clay		11	15	12. Pumping level below land surfaces: <b>18</b> ft. after <b>1</b> hrs. pumping <b>1200</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>1600+</b> g.p.m.		
Brown & white Sandy Clay		15	25	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <b>11-30-74</b>		
Gray Tough Clay		25	36	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Fine sand		36	47	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
Sand & Gravel Clean Coarse Med. loose		47	51	16. Nearest source of possible contamination: ft. <b>1/2 mi</b> Direction <b>West</b> Type <b>Sewer</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Brown Clay & Fine Sand		51	59	17. Pump: _____ Not installed Manufacturer's name <b>WLR</b> Model number <b>SCHC-12</b> HP <b>100</b> Volts _____ Length of drop pipe <b>65</b> ft. capacity <b>1200</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand & Gravel loose med loose		59	71	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rosenrantz - Bemis 134</b> Business name _____ License No. _____ Address <b>Great Bend KS</b> Signed <b>Fredrick Nelson</b> Date <b>9/30/76</b> Authorized representative		
Brown & white Clay		71	76			
Tough Gray Clay		76	80			
Brown Clay		80	86			
Redish Brown Clay & white Rock		86	90			
Sand & Gravel Clean Coarse loose		90	188			
Yellow Brown Sandy Clay (Use a second sheet if needed)		188	190			
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

26  
 15  
 12  
 1/4  
 1/4  
 1/4  
 C/NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5